

RFB 21-001 PEACH COUNTY HEALTH DEPARTMENT ROOF PROJECT

ADDENDUM No. 1

NUMBER:

20PCGJ07RF241

DATE OF ISSUE: 26 MAR 2021

This Addendum forms a part of the contract documents and modifies the original drawings and project manual. Acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject bidder to disqualification.

CHANGES TO, AND CLARIFICATIONS OF, THE SPECIFICATIONS:

Questions from potential bidder appear below and are followed by responses:

1. "In the instructions to bidders under Criteria, what are the requirements for the schedule? Is a CPM schedule requirement or an indication of completion time?"

The schedule is clearly defined in the project manual. A CPM schedule is not required but would certainly be accepted.

2. In the instructions to bidders under Criteria, what is the requirement for the warranty? Section 016100 warranty requirements provides warranty requirements for the project. Do you want sample warranty?

SECTION 01 6100, "WARRANTY REQUIREMENTS, is solely dedicated to describing all the warranty requirements for the project.

SECTION 01 3324.1.04.C.4 clearly requires a sample warranty.

3. Section 011113 Summary of work indicates new 26 ga R panels. Section 074100 indicates 22 ga. What is the thickness requirement for the new R panels?"

26 Gauge.

*All remaining terms and conditions of this solicitation remain unchanged.