



**ADDENDUM NUMBER ONE  
CONTRACT FY2020-074**

**DATE:** November 14, 2019  
**TO:** ALL BIDDERS OF RECORD  
**FROM:** Lyn Majeski, Purchasing Manager  
**BID FOR:** **WOODLAND POCKET PARK TRAIL**

This addendum forms a part of and modifies the bidding specifications for the above item for the City of Oak Ridge, Tennessee.

**ITEM 1 – Changes to Invitation and Instructions to Bidders**

1. FY2020-074 Specifications Page 1 of 1 Sentence 8

Replace: #57 stone with  
“crusher run” stone (TDOT Type A, Grade D) for the trail base.

**ITEM 2 – Questions Received from Potential Bidders**

1. The Scope of Work states the project is a GREENWAY Trail and preparation for Pedestrian Bridge. What needs to be done to prepare for future bridge abatements?  
  
Answer: **This is for trail only – nothing special for bridge but simply butting the trail to the city located bridge connection.**
2. The conceptual plan shows benches, signage, court resurfacing, river stone in creek, riparian soil, site lighting, crosswalk etc. Is this Project ONLY the trail & widened rest areas as detailed in the Specifications?  
  
Answer: **Yes, remaining work items to be completed by others.**
3. Is it possible to prepare a cross section of the trail showing the detail explained in the Specifications as “3” wide edging trim gravel/stone 3” in height”  
  
Answer: **Cross section of trail not available but can be hand sketched.**
4. It appears the Guide Wire for the Utility Pole interferes in a location (or more) of the trail. Will this be re located by ORED?  
  
Answer: **That is the plan but it might be after trail is placed.**

**\*\*\*\*\* Acknowledge receipt of this addendum when you submit your bid \*\*\*\*\***