

City of Beaufort RFP 2021-117 Highway 170 Sidewalk Extension

Questions and Answers

- 1.) Under “Scope of Work” Page 6 of the RFP it states that it is the responsibility of the contractor for coordination with utility providers and to make necessary adjustments. After looking at the site it seems clear to be some gas, water, power, and fiber running adjacent to the exiting sidewalk. Based on the design, will the city utility providers require these items to be totally rerouted or can all/some remain in current locations? This could greatly affect the extent of the area being disturbed as permitted as well as be tough for the contractor to estimate an exact cost.**

Per preliminary coordination with the utilities, there are no known utility conflicts with the proposed improvements and the existing utility lines are to remain in place.

- 2.) Please verify the only curb and gutter to be removed and replaced is located at the (2) entrances as detailed on Sheet 3 of the plans. (265 lf removed and 190 lf replaced per detail on Sheet 3). This would mean the curb and gutter along HWY 170 is to remain.**

Yes, all curb and gutter along SC 170 beyond the existing and proposed driveway locations is to remain.