



## **ADDENDUM NUMBER TWO FOR FY2019-100**

**DATE:** March 8, 2019  
**TO:** ALL PROSPECTIVE BIDDERS  
**FROM:** LYN MAJESKI, PURCHASING MANAGER  
**BID FOR:** WASTEWATER TREATMENT PLANT PLATFORM AND STAIRS AT DIGESTER TANKS

This addendum forms a part of and modifies the bid specifications for the above item currently scheduled to open March 12, 2019 at 2:00 p.m. (local time) at the City of Oak Ridge, Central Services Complex, 100 Woodbury Lane, Oak Ridge, Tennessee.

### **Item 1 – Questions Received**

**I. Question:**

In reference to platform and step walking surfaces: "Bid Document states material to be Metal Bar Gratings (Ref Section 05 50 00 -4 (page), #2.4). Would Extruded Aluminum be an accepted alternative?"

**Response:**

Walking surfaces shall be Metal Bar Gratings in accordance with Section 05 50 00. No alternatives are allowed.

**II. Question:**

In regard to any existing underground conduits in vicinity of southern most footers, will the footers need to be relocated if the conduits are in the way of the proposed location?"

**Response:**

The existing conduits are no longer in use and may be removed if they interfere with footer placement. Cut and plug any cut ends so future modifications to the conduit are allowable. If the conduits are beneath the footer bases by more than six inches, the conduits shall remain in place.

## **Item 2 - Changes to Invitation and Instructions to Bidders**

In regard to installing concrete footers early to allow for proper cure and to allow for any footer adjustments due to other possible underground facilities, the followings shall be changed:

- a. FY2019-100 Invitation to Bid, page 4 of 4, Timeframe for Completion – Delete paragraph and replace with: “The project is allowed one hundred and fifty (150) days for completion from the date of issuance of the notice to proceed by the City. The one hundred and fifty (150) days includes work in the following order: thirty (30) days on-site to install footers; ninety (90) days of no work on-site to procure all other materials for the project; and thirty (30) days to complete the project.
- b. FY2019-100 Contract, page 1 of 4, ARTICLE 2 - Term – Change the construction time for this project from “one hundred twenty (120)” to “on hundred fifty (15)” calendar days.

**\* Acknowledge receipt of this addendum on Page 2 of the Bid Form when you submit your bid \***