



*City of Alamogordo*

Purchasing Dept. • 2600 N. Florida Ave. • Alamogordo, NM 88310 • (575) 439-4115 • FAX (575) 439-4117

April 6, 2020

**ADDENDUM NO. 1  
PUBLIC WORKS BID NO. 2020-002  
GRIGGS FIELD DETENTION BASIN**

Each bidder shall acknowledge receipt of this Addendum Number One (1) by including in the Bid proposal.

Addendum Number 1 is issued to provide changes and/or clarifications to the above referenced PWB as follows:

1. Section 1 – Advertisement for Bids: The Bid Opening date and time remains unchanged. Bids will be opened outdoors, near the northeast corner of 1376 East Ninth Street, Alamogordo, NM. The location change is due to the current COVID-19 pandemic.
2. Section 3- Bid Schedule. A New Bid Item No. 18 has been established. See attached & Revised Bid Schedule and Question No. 8.
3. Pre-bid Conference Sign in Sheet. See attached.
4. **Question:** Please provide detail for the 12' Wide Pond Access Road (is it 6" of asphalt?) and what is the pay item?  
**Answer:** *The proposed 12 ft. wide pond perimeter road does not call for any surfacing, it shall be graded and compacted to the finish grade plan specifications with native earth material. This work is included in the payment for Bid Item No. 2 "Unclassified Excavation".*
5. **Question:** Requesting that N. Florida Ave be shut down during working hours, 6:00 a.m. to 5:30 p.m. and to be reopened at the end of each working day. Option 2 can we use the street 25th and Cuba Ave?  
**Answer:** *Florida Ave. cannot be closed to traffic. No Alternate Haul Route variations will be allowed.*
6. **Question:** Are we able to use 30-50 ton articulated trucks on the dedicated haul route?  
**Answer:** *No. US Department of Transportation compliant trucks shall be used.*

7. **Question:** I see where the truck crossings signs go but do not understand the flagging set up looks like the trucks could cross by their self.

**Answer:** Refer to Sheet 27 of 49 "Traffic Control Plan". Haul trucks shall be "Flagger Controlled" in accordance with the Contract Documents and the Manual on Uniform Traffic Control Devices (latest edition). Contractor has the option of mounting the Florida Ave. traffic control signs on permanent posts, provided that the signs fold over so that they are not displayed after work hours and or when the haul route is not active; conversely, the Contractor may use portable sign stands. The Contractor must remove/take down all Traffic Control devices along Florida Ave. at the end of each shift.

8. **Question:** The roadway surface condition along 26<sup>th</sup> Street may worsen with truck hauling. General Note on Sheet 27 of 49 specifies that "Contractor will be required to maintain/repair any damage to N. Florida and 26<sup>th</sup> St. that may result from hauling." Is this work incidental to Unclassified Excavation?

**Answer:**

A. Contractor shall be responsible for daily maintenance of the haul route consisting of:

i. Best Management Practices; including but not limited to dust control for the entire project site and full length of the haul route, rock entrances and measures to clean up any tracked or spilled debris along Florida Ave and 26<sup>th</sup> Street on a continuous basis. This work shall be paid under Bid Item No. 7 "Temporary Erosion and Sediment Control".

B. New Bid Item No. 18 "Roadway Restoration Allowance" has been established on the Bid Schedule. The allowance will be utilized for any needed pavement and roadway restoration on N. Florida Ave and along 26<sup>th</sup> St. from Florida Ave to Hawaii Ave. including but not limited to hot mix asphalt patching. The City shall self-perform necessary roadway restoration along 26<sup>th</sup> Street from Hawaii Ave. to Cuba Ave. Refer to the attached and revised Bid Schedule.

9. **Question:** What are the Unclassified Excavation Stockpile requirements?

**Answer:** Contractor shall manage the stockpile to reflect the height of the existing embankment. Contrary to what was announced at the pre-bid meeting, the City will not be available to push and manage the stockpile. This effort shall be the Contractors responsibility and shall be incidental to the Bid Item No. 2 "Unclassified Excavation". An alternate stockpile location will be available once the plan location is maximized; this location is within 1000 ft. from the Public Works Gate at the Cuba Ave. intersection.

10. **Question:** Can a demobilization Bid Item be set up?

**Answer:** No. Payment for Bid Item No. 10 "Mobilization" will be made for mobilizing and demobilizing all equipment, tools, all other job-related items to and from the job site. Price will be on a lump sum basis and shall include all equipment, labor, materials, superintendence and all incidentals necessary to become fully mobilized at the start of the project and demobilized when work is complete.

11. **Question:** “The Advertisement for Bid” indicates license classifications needed to bid the project of GF-3, GF-4 or GF-98. We respectfully request the City consider adding a GS-8 classification. Is classification GF-3 and GF-4 both required?  
**Answer:** *Please refer to Subsection A of 14.6.6.8 NMAC. Bidding as a Prime Contractor: (1) A validly licensed person may bid and contract as the prime contractor of a project only if the major portion of the work, based on dollar amount, is authorized by the classification of the prime contractor’s license. Any work outside the scope of the prime contractor’ license classification(s) must be subcontracted.*  
*The authorized project classification for this project is either GF-4 or GF-98. Note, GF-3 and GS-8 are not authorized project classifications.*
12. **Question: Is there a designated location for the clearing and grubbing material?**  
**Answer:** *No. Contractor shall be responsible for disposing of all vegetation and debris to an environmentally suitable site, this work is considered incidental to the Bid Item No. 1 “Clearing and Grubbing”.*
13. **Question:** What is the price rate for construction effluent water?  
**Answer:** *For Reclaimed Water Rates and to obtain a meter, contact Water Billing at 575.439.4260. Locations of Reclaimed Water Hydrants are listed in Article 01-002.1 General Requirements, Section 3.0.*
14. **Question:** Will backfill material be required for pipe since the native material will be used for everything else?  
**Answer:** *The storm drain bedding and backfill requirements are defined in the Supplemental Technical Specifications. Contractor may utilize on-site material provided that it complies with the specification requirements. Bedding and Backfill is considered incidental to Bid item No. 6 “24 Inch Culvert Pipe Smooth Interior”.*
15. **Question:** We would like to propose a substitution for the proposed reflectors that are to be placed on the bollards. The reflector buttons are likely to be broken off fairly easily and will have a limited reflective angle. We would like to use a 3M Conspicuity Marking tape that would wrap around then entire pole and be completely weather proof thus lasting much longer and reflecting from all angles.  
**Answer:** *Yes. 3M Conspicuity Marking Tape is an approved substitution.*
16. **Question:** Additive Alternates Bid Item No. A-1. What size is the chain to be used?  
**Answer:** *Chain shall be a welded coil chain, Grade 30 zinc plated finish, measuring 3/8 inch diameter.*

17. **Question:** Can the salvaged riprap and metal stakes be used as material for the proposed rip rap.

**Answer:** *Yes. The existing on-site rip rap with an approximate quantity of 81 cubic yards and steel stakes shall be reused in the proposed rip rap locations. The reused riprap will not be measured and paid for separately from the imported and placed riprap (Bid Item No. 8). The Contractor shall receive payment for removing and temporary stockpiling the rip rap and steel stakes under Bid Item No. 17 "Removal of Structures and Obstructions". Contractor will then receive payment for installing the on-site rip rap under Bid Item No. 8."Wire Enclosed Rip Rap"*

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made part of the Contract Documents. Each bidder shall acknowledge receipt of this Addendum Number One (1) using this acknowledgement page and submit with the Bid proposal.

Sincerely,

Barbara Pyeatt  
Chief Procurement Officer

Received By: \_\_\_\_\_

Date Received: \_\_\_\_\_

Business Name: \_\_\_\_\_

Signature: \_\_\_\_\_

**SECTION 3 - BID SCHEDULE**  
**REVISED: ISSUED VIA ADDENDUM NO. 1**

BIDDER agrees to perform all of the work described in the specifications and shown on the plans for the following unit or lump sum prices. Prices should be written in numerals in the spaces provided.

**Public Works Bid No. 2020 - 002**  
**Griggs Field Detention Basin**

<b>BID ITEM NO.</b>	<b>ITEM DESCRIPTION</b>	<b>UNIT</b>	<b>EST. QTY.</b>	<b>UNIT PRICE</b> (please use typewriter or print legibly)	<b>AMOUNT</b> (please use typewriter or print legibly)
1	CLEARING & GRUBBING	LS	1		
2	UNCLASSIFIED EXCAVATION	CY	37,500		
3	REINFORCED CONCRETE FOR SPILLWAY; INCL. CONCRETE, REINFORCEMENT, SUBGRADE PREPARATION	CY	46		
4	CONCRETE SLOPE BLANKET FOR 60-INCH CMP; INCL. CONCRETE, REINFORCEMENT, SAFETY GRATE; MITER TO 4:1 SLOPE	EA	1		
5	CONCRETE FOR CUTOFF WALLS; INCL. CONCRETE, SUBGRADE PREPARATION	CY	15		
6	24" SMOOTH INTERIOR CULVERT PIPE; INCL. 2 - TEE FITTINGS	LF	120		
7	TEMPORARY EROSION AND SEDIMENT CONTROL	LS	1		
8	WIRE ENCLOSED RIPRAP CLASS A; INCL. SUBGRADE PREPARATION	CY	370		
9	TRAFFIC CONTROL MANAGEMENT	LS	1		
10	MOBILIZATION	LS	1		
11	CONSTRUCTION STAKING BY THE CONTRACTOR	LS	1		
12	POST CONSTRUCTION PLANS	LS	1		
13	DRY WELL, COMPLETE	LS	1		
14	STORM DRAIN MANHOLE/CLEANOUT MODIFIED; COMPLETE INCL. 24 1/8" RING AND 23 3/4" LID	EA	2		
15	UTILITY ALLOWANCE	AL	1	\$5,000.00	\$5,000.00
16	PROTECTION OF PROJECT FROM WATER DURING CONSTRUCTION	LS	1		
17	REMOVAL OF STRUCTURES AND OBSTRUCTIONS	LS	1		
18	ROADWAY RESTORATION ALLOWANCE	AL	1	\$10,000.00	\$10,000.00

SUBTOTAL BID ITEMS 1-18

\$ \_\_\_\_\_

CONSTRUCTION ADDITIVE ALTERNATES					
BID ITEM NO.	ITEM DESCRIPTION	UNIT	EST. QTY.	UNIT PRICE (please use typewriter or print legibly)	AMOUNT (please use typewriter or print legibly)
A-1	POST AND CHAIN BARRIER	EACH	2		
A-2	8' CHAINLINK FENCE WITH BARBERD WIRE	LF	1,080		
A-3	10' CHAINLINK DOUBLE GATE WITH BARBED WIRE	EACH	1		

SUBTOTAL BID ITEMS A1-A3

\$ \_\_\_\_\_

**TOTAL BASE BID + TOTAL BID ALTERNATE AMOUNT** – Amount derived from items 1-18 &

A-1 – A-3 above, excluding NMGR (use of words followed by numeric):

\_\_\_\_\_

\_\_\_\_\_

(\$ \_\_\_\_\_)

**The Lowest Bid will be determined based on the lowest combined total amount for the base bid plus bid alternates. The owner reserves the right to accept/reject any and/or all of the bid alternatives included in the bid form.**

**NOTE: Gross receipts tax shall be paid with each pay request as it is submitted at the current tax rate for the City of Alamogordo, New Mexico (8.0%)**

To the City of Alamogordo, New Mexico (hereinafter called "OWNER"), the undersigned, (hereinafter called "BIDDER"), in compliance with your invitation for bids for the construction of **Griggs Field Detention Basin, Public Works Bid No. 2020 - 002**, having carefully examined the Contract Documents and the site of the proposed work, and being familiar with all of the conditions surrounding the construction of the proposed project including the availability of materials and labor, hereby proposes to furnish all labor, materials, and supplies, and to construct the project in accordance with the Contract Documents, within the time set forth herein, and at the unit prices stated above. These prices are to cover all expenses incurred in performing the work required under the Contract Documents of which this Bid Schedule is a part. Quantities shown in this Bid Schedule are estimated and actual payment will be made on the basis of the unit bid prices for confirmed quantities as constructed.

BIDDER acknowledges receipt of the following addenda: \_\_\_\_\_

**CALLOUT NOTICE ACKNOWLEDGMENT:**

\_\_\_\_\_  
Authorized Signature of Bidder

\_\_\_\_\_  
Business Name of Bidder

\_\_\_\_\_  
Authorized Signature of Bidder

\_\_\_\_\_  
Printed Name and Title of Authorized Signature

\_\_\_\_\_  
BIDDER'S New Mexico Contractor's License No. & Classification

\_\_\_\_\_  
Address

\_\_\_\_\_  
Telephone

\_\_\_\_\_  
Fax

(SEAL) If Bid Proposal is submitted by a corporation

