



Board of County Commissioners • Escambia County, Florida

Paul R. Nobles/Purchasing Manager  
Office of Purchasing

September 11, 2018

To: All Known Prospective Bidders

**Addendum Number 3:**

RE: Central Energy Plant Control  
Specification Number: PD 17-18.089

All:

The following information request has been received. The responses are included with this addendum as attachments.

This Addendum Number 3 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your proposal as an acknowledgement of you having received same. You may photo copy for your record.

Sincerely,

Buzz Roggenbuck  
Sr. Purchasing Coordinator

Acknowledgement of Receipt of Addendum 3

SIGNED: \_\_\_\_\_

COMPANY: \_\_\_\_\_

PD 17-18.089 Central Energy Plant Control - Addendum #3:

Request for information:

1. Most recent Eddy Current reports for all listed chiller's heat exchangers.
2. Most recent comprehensive Annual shut down inspection reports for all listed equipment.
3. July/August 2018 operating inspection reports for all listed equipment.
4. Age of listed equipment.
5. Most recent refrigerant and oil analysis reports for all chillers listed.
6. Most recent contract, including the awarded price.
7. List of any major repairs done on all listed equipment in the last 3 years.

## ATTACHMENTS

M.C. Blanchard Judicial Ctr.

January 2017

1.20.17 - Bi-Monthly Inspection

February 2017

2.6.17 - Bi-Monthly Inspection and Completed Annual Inspection on Chillers.

2.28.17 - Completed first Cooling Tower Annual Inspection

3.1.17 - Completed second Cooling Tower Annual Inspection and started on wooden Cooling Tower Annual Inspection.

March 2017

03.02.17 - 03.03.17 - Monthly Inspection-Continued cleaning first and second cooling towers

03.17.17 -Bi-Monthly Inspection

03.24.17 - Continued Bi-Monthly Inspection

03.27.17 - Cooling tower -Found the fill valve leaking, ordered new valve.

03.31.17 - Cooling tower- switched down chiller #4 and removed and replaced the valve and adjusted the other valve. Closed up tower and restarted chiller.

April 2017

4.14.17 - Bi-Monthly Inspection - Inspected Chiller and Towers for proper operation and cleanliness. Lubed cooling towers and pumps. Check motors and contactors.

4.21.17 - Chiller going off on surge - Did an annual log, could not find a problem with the unit but found cooling tower fan would not operate in the auto position, but would in hand.

Cooling tower sump temp sensor is reading 250 degrees and this is the point that controller is reading to start and stop the fans.

4.21.17 - Bi-Monthly Inspection - Changed Oil Filter. Cleaned Starter Strainer and changed Starter Coolant on Chiller 2. Ran Chiller 2 and tested for proper operation.

May 2017

5.12.17 - Bi-Monthly Inspection - Inspected Towers, Chillers, Pumps, and Drives. Checked electrical and motors. Logged Chillers. PM Complete. No follow up recommended.

5.31.17 - Bi-Monthly Inspection - Logged Chillers. Inspected Pumps, Towers, Drives for proper operation and cleanliness. PM Complete.

9.27.17 - Cooling tower was drained. Cut the PVC out and the eight-inch steel pipe and remade the connection. Welded up the fitting. Bolted back up and filled back up. Checked for leaks, started up the pumps, and bled off all air. Started the chillers up.

9.28.17 - Returned and painted the piping and finished cleaning out the cooling tower spray nozzles.

9.28.17 - Bi-Monthly Inspection - Cleaned out the nozzles on wooden cooling towers.

9.29.17 - Bi-Monthly Inspection - Inspected chillers, towers, pumps, and drives. Logged chillers.

#### October 2017

10.12.17 - Bi-Monthly Inspection - Logged chillers and inspected all HVAC equipment for proper operation.

10.23.17 - Bi-Monthly Inspection - Inspected cooling towers and pumps for proper operation and cleanliness.

10.24.17 - Bi-Monthly Inspection - Inspected chillers, towers, pumps and drives for proper operation and cleanliness.

#### November 2017

11.13.17 - Bi-Monthly Inspection - Logged the two chillers. #4 is off line due to shaft seal being bad.

11.22.17 - Bi-Monthly Inspection

11.28.17 - Bi-Monthly Inspection - Greased all the pumps.

11.29.17 - Bi-Monthly Inspection - Logged the two chillers and finished the Cooling Tower inspection.

11.30.17 - Bi-Monthly Inspection - Logged chiller #4.

#### December 2017

12.4.17 - Bi-Monthly Inspection - Added oil to chiller #4

12.6.17 - Bi-Monthly Inspection - Logged chiller #4

1.3.18 - Bi-Monthly Inspection - Logged chiller #2 and started inspection on #1

1.4.18 - Bi-Monthly Inspection - Finished chiller logs and put #1 starter back together

#### January 2018

1.17.18 - Annual Inspection - Started Annuals on #1-2. Logged three.

1.26.18 - Annual Inspection - Started the Annuals on #1-4 megged motors and got oil samples from all logged #4.

2.5.18 - Annual Inspection - Pulled the heads off of #1-4 and brushed the tubes. Need to return and finish the tubes on the #4 machine and put the head back on and get ready to run to get #2 off line.

Annual Inspection - Brushed tubes on Chiller #4.  
2.7.18 - Annual Inspection - Returned to put condenser head back on #4 and leak checked. Merged the motor and tighten all connection to compressor. Changed all oil and inductor filter and switch back into service.

#### February 2018

2.19.18 - Bi-Monthly Inspection - Drained and removed condenser head to brush tubes. Put back together and did running log on #4.  
2.22.18 - Bi-Monthly Inspection - Finished Chiller Logs

#### March 2018

3.16.18 - Bi-Monthly Inspection - Found all chillers went down night before and that #1-4 would not start. Found #4 down on Lube Alarm and had a blown fuse on the 115-volt side. Replaced and checked operations. Logged the chillers and greased the pumps and the cooling towers.  
3.28.18 - Bi-Monthly Inspection - Greased the pumps and started on logging the chillers.  
3.29.18 - Logged the 3 chillers and greased the cooling towers for the #1-2 chillers.

#### April 2018

4.11.18 - Bi-Monthly Inspection - Started PM on cooling towers  
4.12.18 - Bi-Monthly Inspection - Finished PM  
4.25.18 - Bi-Monthly Inspection - Logged both chillers. #4 off due to the evap. Checked cooling towers and pumps.

#### May 2018

5.22.18 - Bi-Monthly Inspection - Started PM on the chillers  
5.25.18 - Bi-Monthly Inspection - Finished checking the cooling towers and the pumps. Logged the running chillers.

#### June 2018

6.15.18 - Bi-Monthly Inspection - Greased the pumps.  
6.21.18 - Bi-Monthly Inspection - Finished logging the 3 chillers and checked cooling towers.

#### July 2018

7.12.18 - Bi-Monthly Inspection - Started and ran the 3 chillers. Logged each, checked towers and pumps.  
7.18.18 - Chiller Down - Found the suction pressure transducer bad. Replaced. Also found problem with refrigerant float. Got the unit running, return to troubleshoot.

7.25.18 - Chiller #1 & #2 Issues - Chiller #1 has issues with dual oil filter block. Changed oil filter and switched to right filter. Brought chiller online. Chiller #2 removed plugs from starter board. Checked and cleaned pins. Reinstalled and started chiller. Chiller was left online.

7.25.18 - Bi-Monthly Inspection - Logged the chiller.

## West Florida Regional Library

January 2017

1.4.17 - Bi-Monthly Inspection  
1.20.17 - Bi-Monthly Inspection  
1.31.17 - Found the boiler shut down and both loop and drive pumps shut down. Removed all the panels to the boiler and found a spare coupling in the back. Locked out the boiler and removed the motor from the pump. Found the motor drive worked loose and would not seat on the motor shaft. Cleaned up the drive sides of the motor and the pump and replaced the set screws. Reinstalled the motor back on the pump. Ordered two replacement couplings. Checked operation, all normal. Looked at the chiller and found that someone had moved the set point to 58. Moved back down to 44 and watched operation.

February 2017

2.1.17 - Bi-Monthly Inspection

March 2017

03.08.17 - Bi-Monthly Inspection

03.27.17 - Bi-Monthly Inspection

April 2017

4.7.17 - Chiller shutting off on No Flow. Chill water pump and the bypass valve was opening and closing very fast. Customer said that the dp on the #4 AHU was losing signal and that we needed to put the bypass into manual and the unit would be ok until they could get the dp switch replaced.

4.13.17 - Bi-Monthly Inspection - Logged Chiller. Inspected Pumps and Boiler

4.23.17 - Float Sensor Replacement - Bad Flow Sensor. Shut off the pump, valved out drained water, and removed the switch. Put in new switch, bled off, and valved back in. Checked Operation. Water got down to 42 degrees and new Flow Sensor was reading correctly.

4.24.17 - Flow Sensor Tripped - Found 8 pounds of drop, minimum is 3. Reset and checked operation. Flow went down under minimum set point and the chiller tripped the switch but did an auto-reset. Trane was there and found a d-p on the AHU 7 that was not reading the correct d-p and was working the bypass and the pump speed off this sensor. Issue with the controls, not the chiller.

4.27.17 - Bi-Monthly Inspection - Logged Chiller. Inspected Boiler and Pumps.



May 2018

5.22.18 - Bi-Monthly Inspection - Inspected Boiler, Chiller, Pumps, and Drives

6.5.18 - Bi-Monthly Inspection - Inspected Chiller, Boiler, Pumps, and Drives

June 2018

6.15.18 - Bi-Monthly Inspection - Inspection of boiler, pump drives. Grease motor, inspect chiller and log.

6.27.18 - Bi-Monthly Inspection - Inspect chiller, boiler, pumps and drives.

July 2018

7.16.18 - Bi-Monthly Inspection - Inspect chiller and boiler. The chiller is making setpoint. The boiler is working properly also.

8.2.18 - Bi-Monthly Inspection - Log and inspect chiller. Inspected pumps and drives. Bypassed relay to start boiler after putting hot water pump in hand. Ran to 150° before turning back to auto. Boiler relay start/stop intermittent as is the pump. Talked with ECBCC tech and he said he was waiting on a controls tech.

## Central Office Complex

### January 2017

- 1.18.17 - Bi-Monthly Inspection of Trane Chiller. Attempted Bi-Monthly Inspection of Smardt Chiller but could not switch over.
- 1.26.17 - Bi-Monthly Inspection of Trane Chiller. Attempted Bi-Monthly Inspection of Smardt Chiller but could not run.

### February 2017

- 2.8.17 - Bi-Monthly Inspection of Trane Chiller and Smardt Chiller
- 2.20.17 - Bi-Monthly Inspection of Trane Chiller. Attempted Bi-Monthly Inspection of Smardt Chiller but could not get switched over.

### March 2017

- 03.20.17 - Bi-Monthly Inspection of Trane Chiller and Smardt Chiller
- 03.31.17 - Bi-Monthly Inspection of Trane Chiller. Was unable to switch over the Smardt to run log sheet.

### April 2017

- 4.11.17 - Bi-Monthly Inspection of Trane Chiller and Smardt Chiller. Could not get the Smardt Chiller changed over.
- 4.20.17 - Bi-Monthly Inspection. Logged Trane Chiller and greased the pumps. Called and had the Chiller switched over.

### May 2017

- 5.15.17 - Bi-Monthly Inspection of Trane Chiller and Smardt Chiller. Logged the Trane Chiller and called FMD to switch over to the Smardt and could not get switched.
- 5.18.17 - Smardt Chiller in Fault. Smardt Chiller Compressors have tripped out on High Inverter Temp (156\*) alarm on 4/21/17. Chiller has not been run since then. Reset all alarms. Had George start chiller and monitored all compressor electronics temperatures. All temps are running well below safety limits. Unknown at this time why compressors ran warm in April. Possible cool weather refrigerant stacking in condenser coils. George will advise on any further trouble.
- 5.23.17 - Smardt Chiller has locked out fault on Inverter Temp. Reset Chiller, compressor 2 is off due to high inverter temperature. Started to rain which prevented opening up unit. Will return.
- 5.24.17 - Return on Smardt Chiller lock out fault on Inverter Temp. Found Chiller Compressor #2 tripped off on Inverter Temp.

NOVEMBER 2017

11.9.17 - Bi-Monthly Inspection - Logged the Trane chiller. The Smardt chiller was offline.

11.22.17 - Bi-Monthly Inspection - Logged the Trane chiler and called FMD to switch over, but there was no one there.

December 2017

12.11.17 - Bi-Monthly Inspection - Logged the two chillers

12.28.17 - Bi-Monthly Inspection - Logged the Trane chiller

January 2018

1.23.18 - Bi-Monthly Inspection - Logged the two chillers

2.1.18 - Bi-Monthly Inspection - Got the Smardt Chiller switched over so that it could be logged.

February 2018

2.21.18 - Bi-Monthly Inspection - Started and ran both chillers

3.2.18 - Bi-Monthly Inspection - Inspected chiller and logged

March 2018

3.9.18 - Bi-Monthly Inspection - Logged Trane Chiller

3.27.18 - Bi-Monthly Inspection - Logged Trane Chiller and Smardt Chiller

April 2018

4.12.18 - Bi-Monthly Inspection - Checked in with customer over the phone. Logged the Trane chiller and had the Smardt chiller switched over and logged it.

4.27.18 - Bi-Monthly Inspection - Logged the Smardt chiller. At this time the Trane chiller was off line.

May 2018

5.25.18 - Bi-Monthly Inspection - Logged both of the Chillers

6.7.18 - Bi-Monthly Inspection - Logged the Trane Chiller, it was the only one running at the time.

June 2018

6.12.18 - Bi-Monthly Inspection - Logged both of the Chillers on site.

6.27.18 - Bi-Monthly Inspection - Logged the Trane Chiller. Could not get the Smardt Chiller switched over.

July 2018

7.17.18 - Bi-Monthly Inspection - Logged the Trane chiller. Could not get the Smardt switched over.

7.25.18 - Bi-Monthly Inspection - Checked in with the customer. Logged the Trane chiller. Smardt chiller offline at the time.

CDC

January 2017

1.27.17 - Bi-Monthly inspection

February 2017

2.3.17 - Bi-Monthly Inspection

2.20.17 - Bi-Monthly Inspection

March 2017

03.20.17 - Bi-Monthly Inspection

April 2017

4.12.17 - Bi-Monthly Inspection

4.25-4.26.17 - Bi-Monthly Inspection

May 2017

5.17.17 - Bi-Monthly Inspection

5.31.17 - Bi-Monthly Inspection

June 2017

6.12.17 - Bi-Monthly Inspection

6.28.17 - Bi-Monthly Inspection

July 2017

7.20.17 - Bi-Monthly Inspection

August 2017

8.9.17 - Bi-Monthly Inspection

8.14.17 - Bi-Monthly Inspection - Greased all motors and pumps, inspected and logged chillers, checked electrical.

8.30.17 - Bi-Monthly Inspection - Inspect pumps, chillers, drives, controls, and log chillers.

September 2017

9.11.17 - Bi-Monthly Inspection

9.20.17 - Bi-Monthly Inspection - Cleaned coils on chiller 2 & 3 condensers

October 2017

10.3.17 - Bi-Monthly Inspection - Inspect chillers and pumps. Clean coil on chillers 1 and 3.

10.27.17 - Bi-Monthly Inspection - Inspect chillers, pumps, and valves. Log chillers.

November 2017

June 2018

6.15.18 - Bi-Monthly Inspection - Inspect chillers, grease pump motors, valves and drives

6.19.18 - Central Plant Chiller #3 - Chiller 3 offline due to Compressor 2A Starter Module issue. Will need to replace bearings on Chill Water Pump #2 after module is replaced.

6.27.18 - Central Plant Chiller #3 - Installed Starter Module for compressor. Unlocked compressor, restarted chiller.

6.27.18 - Bi-Monthly Inspection - Inspect chillers, pumps, have issues with Pump #2.

July 2018

7.17.18 - Bi-Monthly Inspection - Logged the #1-#3 chillers. Checked all fan motors and fans.

8.2.18 - Bi-Monthly Inspection - Log chillers, inspect pumps. Drives pump 2 still needs repairs and chiller #3 CH530 controller needs to be replaced.

# Engineered Cooling Services

Building Efficiency and Sustainability



A Service Logic Company

February 9, 2018

Escambia County Board of County Commissioners  
PO Box 1591  
Pensacola, FL 32591-1591

Attn: George Puel

SUBJECT: OIL ANALYSIS REPORT

Dear Mr. Puel:

Please find attached copies of the laboratory oil analysis taken during the preventive maintenance service for the following:

<b>Model #</b>	<b>Serial #</b>	<b>Location</b>	<b>See Note</b>
YSDCCD53-CLC	SDGM960510	Blanchard – Chiller 1	
YKK	SBXM852570	Blanchard – Chiller 2	Moisture Level
YKFB 800	SBNM245900	Blanchard – Chiller 4	Moisture Level

All wear metals, moisture, and acid were in satisfactory ranges, unless otherwise indicated above. If noted above, please see detailed Oil Analysis Report for further information.

If there are any questions please don't hesitate to call.

Best Personal Regards,

Ray Rodriguez  
Executive Vice President



**TRANE**

Trane Chemical Laboratory

Oil Analysis

ENGINEERED COOLING SERVICES

2801 N DAVIS HWY

PENSACOLA, FL 32503

Phone Number:

Lab Number:

021803720

Served By:  
ENGINEERED COOLING SERVICES

Purchase Order:  
20202

Serial Number:  
SDGM960510

Equipment Owner:  
ESCAMBIA COUNTY

Location:  
BLANCHARD/CH-1

Model:  
YSPCCD53-CLC

\* O = Oil Changed, B = Bearing, R = RNewal

Sample Number	Date Analyzed	Service Period	*	Oil Type	Physical Data				Wear Metal Data (in parts per million)						
					Moisture PPM	Total Acid	Aluminum	Chromium	Copper	Iron (Fe)	Lead	Tin	Zinc		
050714353	5/29/07			YORK S	170	0.0559	2	1	4	159	1	12	4		
100729073	10/1/07			YORK S	142	0.0864	0	0	3	120	0	7	3		
040811024	4/11/08			YORK S	83	0.0719	0	0	2	125	0	8	3		
090830968	9/24/08			YORK S	166	0.0825	0	0	3	123	0	10	3		
020904445	2/13/09			YORK S	75	0.0816	0	0	2	135	0	9	6		
021004241	2/15/10	17567 Hours		YORK	66	0.0396	0	0	2	127	0	8	4		
041313210	4/19/13			YORK	132	0.0423	0	0	24	77	1	6	4		
081325712	8/12/13				323	0.0706	1	0	16	67	0	6	3		
041412059	4/9/14	18154 Hours		YORK P	168	0.0235	0	0	38	80	0	6	5		
031508422	3/5/15			YORK	74	0.0435	0	0	35	78	1	6	5		
021603598	2/2/16	0 Hours	O		155	0.0482	1	0	48	74	0	6	4		
021803720	2/8/18	0 Hours		YORK C	77	0.0264	0	0	3	5	0	1	1		



Trane Chemical Laboratory

# Oil Analysis

ENGINEERED COOLING SERVICES  
 2801 N DAVIS HWY  
 PENSACOLA, FL 32503  
 Phone Number:

Lab Number:	021803720	Serviced By:	ENGINEERED COOLING SERVICES	Purchase Order:	20202
Serial Number:	SDGM960510	Equipment Owner:	ESCAMBIA COUNTY	Location:	BLANCHARD/CH-1
				Model:	YSDCCD33-CLC

**090627929** 9/23/06

The iron level is high

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**050714353** 5/29/07

The iron level is high.

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**100729073** 10/1/07

The iron level is high.

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**040811024** 4/11/08

The iron level is high

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**090830968** 9/24/08

The iron level is high

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**020904445** 2/13/09

The iron level is high.

Acid number, moisture, and other wear metals are satisfactory ranges.





Trane Chemical Laboratory

# Oil Analysis

ENGINEERED COOLING SERVICES  
 2801 N DAVIS HWY  
 PENSACOLA, FL 32503  
 Phone Number:

Lab Number: 021803720      Serviced By: ENGINEERED COOLING SERVICES  
 Serial Number: SDGM960510      Equipment Owner: ESCAMBIA COUNTY  
 Location: BLANCHARD/CH-1      Purchase Order: 20202  
 Model: YSDCCD53-CLC

Resample in 3-4 months or 2500 hours

**021004241**      **2/15/10**

The iron level is high

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**041313210**      **4/19/13**

The iron level is high

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**081325712**      **8/12/13**

Moisture level is high which may be due to contamination in transit or the hygroscopic nature of this oil type (if using POE).

The iron level is high.

Acid number and other wear metals are satisfactory.

Resample in 3-4 months or 2500 hours.

**041412059**      **4/9/14**

The iron level is high

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours

**031508422**      **3/5/15**

The iron level is high

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**021603598**      **2/2/16**



**TRANE**

Trane Chemical Laboratory

### Oil Analysis

ENGINEERED COOLING SERVICES  
2801 N DAVIS HWY  
PENSACOLA, FL 32503

Phone Number:

Lab Number:  
021803720

Serviced By:  
ENGINEERED COOLING SERVICES

Purchase Order:  
20202

Serial Number:  
SDGM960510

Equipment Owner:  
ESCAMBIA COUNTY

Location:  
BLANCHARD/CH-1

Model:  
YSDCCD53-CLC

The copper and iron levels are high.

Acid number, moisture, and other wear metals are satisfactory ranges.

Resample in 3-4 months or 2500 hours.

**021803720**

**2/8/18**

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.

Resample in 3-4 months or 2500 hours.



**TRANE**

Trane Chemical Laboratory

# Oil Analysis

ENGINEERED COOLING SERVICES

2801 N DAVIS HWY

PENSACOLA, FL 32503

Lab Number:  
021803720

Served By:  
ENGINEERED COOLING SERVICES

Purchase Order:  
20202

Phone Number:


Serial Number:  
SDGM960510

Equipment Owner:  
ESCAMBIA COUNTY


Location:  
BLANCHARD/CH-1

Model:  
YSDCCD53-CLC


## Moisture




## Acid



## Tin



## Zinc



# Engineered Cooling Services

Building Efficiency and Sustainability



A Service Logic Company

February 9, 2018

Escambia County Board of County Commissioners  
PO Box 1591  
Pensacola, FL 32591-1591

Attn: George Puel

SUBJECT: OIL ANALYSIS REPORT

Dear Mr. Puel:

Please find attached copies of the laboratory oil analysis taken during the preventive maintenance service for the following:

<b>Model #</b>	<b>Serial #</b>	<b>Location</b>	<b>See Note</b>
YSDCCD53-CLC	SDGM960510	Blanchard – Chiller 1	
YKK	SBXM852570	Blanchard – Chiller 2	Moisture Level
YKFB 800	SBNM245900	Blanchard – Chiller 4	Moisture Level

All wear metals, moisture, and acid were in satisfactory ranges, unless otherwise indicated above. If noted above, please see detailed Oil Analysis Report for further information.

If there are any questions please don't hesitate to call.

Best Personal Regards,

Ray Rodriguez  
Executive Vice President



TRANE

Trane Chemical Laboratory

Oil Analysis

ENGINEERED COOLING SERVICES  
2801 N DAVIS HWY  
PENSACOLA, FL 32503

Phone Number:

Lab Number:  
021803721

Served By:  
ENGINEERED COOLING SERVICES

Purchase Order:  
20202

Serial Number:  
SBXM852570

Equipment Owner:  
ESCAMBIA COUNTY

Location:  
BLANCHARD/#2

Model:  
YKK

\* O = Oil Changed, B = Bearing, R = Renewal

Sample Data

Physical Data

Wear Metal Data (in parts per million)

Sample Number	Date Analyzed	Service Period	* Oil Type	Moisture PPM	Total Acid	Aluminum	Chromium	Copper	Iron (Fe)	Lead	Tin	Zinc
041313209	4/19/13	5119 Hours	YORK K	146	0.0430	0	0	0	0	0	0	0
041412060	4/9/14	8994 Hours	YORK K	33	0.0450	0	0	0	1	1	0	1
031508423	3/5/15		YORK	19	0.0366	0	0	0	1	0	0	0
021603596	2/2/16	0 Hours	YORK K	152	0.0322	1	0	0	1	0	1	0
021803721	2/8/18	0 Hours	YORK K	897	0.0472	0	0	0	0	0	0	0



**TRANE**

Trane Chemical Laboratory

Oil Analysis

ENGINEERED COOLING SERVICES  
 2801 N DAVIS HWY  
 PENSACOLA, FL 32503  
 Phone Number:

Lab Number: 021803721  
 Serial Number: SBXXM852570  
 Served By: ENGINEERED COOLING SERVICES  
 Equipment Owner: ESCAMBIA COUNTY  
 Location: BLANCHARD/#2  
 Purchase Order: 20202  
 Model: YKK

**041313209** 4/19/13

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**041412060** 4/9/14

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**031508423** 3/5/15

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**021603596** 2/2/16

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**021803721** 2/8/18

Moisture level is high which may be due to contamination in transit or the hygroscopic nature of this oil type (if using POE).  
All wear metals and acid number are in satisfactory ranges for the model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.





**TRANE**

Trane Chemical Laboratory

Oil Analysis

ENGINEERED COOLING SERVICES  
2801 N DAVIS HWY  
PENSACOLA, FL 32503

Phone Number:

Lab Number:  
021803721

Serial Number:  
SBXM1852570

Serviced By:  
ENGINEERED COOLING SERVICES


Equipment Owner:  
ESCAMBIA COUNTY

Location:  
BLANCHARD/#2


Purchase Order:  
20202

Model:  
YKK


**Moisture**




**Tin**



**Acid**



**Zinc**



# Engineered Cooling Services

Building Efficiency and Sustainability

A Service Logic Company

February 9, 2018

Escambia County Board of County Commissioners  
PO Box 1591  
Pensacola, FL 32591-1591

Attn: George Puel

SUBJECT: OIL ANALYSIS REPORT

Dear Mr. Puel:

Please find attached copies of the laboratory oil analysis taken during the preventive maintenance service for the following:

<b>Model #</b>	<b>Serial #</b>	<b>Location</b>	<b>See Note</b>
YSDCCD53-CLC	SDGM960510	Blanchard – Chiller 1	
YKK	SBXM852570	Blanchard – Chiller 2	Moisture Level
YKFB 800	SBNM245900	Blanchard – Chiller 4	Moisture Level

All wear metals, moisture, and acid were in satisfactory ranges, unless otherwise indicated above. If noted above, please see detailed Oil Analysis Report for further information.

If there are any questions please don't hesitate to call.

Best Personal Regards,

Ray Rodriguez  
Executive Vice President





Trane Chemical Laboratory

ENGINEERED COOLING SERVICES  
2801 N DAVIS HWY  
PENSACOLA, FL 32503  
Phone Number:

**TRANE**

Oil Analysis

Lab Number:  
021803722

Served By:  
ENGINEERED COOLING SERVICES

Purchase Order:  
20202

Serial Number:  
SBNM245900

Equipment Owner:  
ESCAMBIA COUNTY

Location:  
BLANCHARD/CH-4

Model:  
YKFB 800

Sample Data				Physical Data										Wear Metal Data (in parts per million)			
Sample Number	Date Analyzed	Service Period	* Oil Type	Moisture PPM	Total Acid	Aluminum	Chromium	Copper	Iron (Fe)	Lead	Tin	Zinc					
090629338	10/4/06		YORK K	94	0.0225	0	0	0	0	0	0	0					
050714359	5/29/07		YORK K	162	0.0194	1	0	1	2	0	2	1					
100729071	10/1/07		YORK K	81	0.0226	0	0	0	1	0	0	0					
040811022	4/11/08		YORK K	76	0.0167	0	0	0	0	0	0	0					
090830962	9/24/08		YORK K	82	0.0142	0	0	0	1	0	0	0					
020904448	2/13/09		YORK K	26	0.0166	0	0	0	1	0	0	1					
021004239	2/15/10	35845 Hours	YORK	47	0.0186	0	0	0	1	0	0	0					
041313208	4/19/13	54799 Hours	YORK K	95	0.0171	1	0	0	1	0	0	0					
041412061	4/9/14	60471 Hours	YORK K	49	0.0209	1	0	0	1	1	0	1					
031508424	3/5/15		YORK	32	0.0253	0	0	0	2	0	0	0					
021603597	2/2/16	0 Hours	YORK K	201	0.0299	0	0	1	0	0	0	0					
021803722	2/8/18	0 Hours		578	0.0278	0	0	0	0	0	1	0					

\* O = Oil Changed, B = Bearing, R = RNewal



**TRANE**

Trane Chemical Laboratory

ENGINEERED COOLING SERVICES  
 2801 N DAVIS HWY  
 PENSACOLA, FL 32503  
 Phone Number:

# Oil Analysis

Lab Number: 021803722      Serviced By: ENGINEERED COOLING SERVICES      Purchase Order: 20202  
 Serial Number: SBNM245900      Equipment Owner: ESCAMBIA COUNTY      Location: BLANCHARD/CH-4      Model: YKFB 800

**090629338**      10/4/06

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**050714359**      5/29/07

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**100729071**      10/1/07

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**040811022**      4/11/08

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**090830962**      9/24/08

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**020904448**      2/13/09

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**021004239**      2/15/10

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.  
Resample in 3-4 months or 2500 hours.

**041313208**      4/19/13



**TRANE**

Trane Chemical Laboratory

ENGINEERED COOLING SERVICES

2801 N DAVIS HWY

PENSACOLA, FL 32503

Phone Number:

# Oil Analysis

Lab Number:  
021803722

Serviced By:  
ENGINEERED COOLING SERVICES

Purchase Order:  
20202

Serial Number:  
SBNM245900

Equipment Owner:  
ESCAMBIA COUNTY

Location:  
BLANCHARD/CH-4

Model:  
YKFB 800

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported

Resample in 3-4 months or 2500 hours

**041412061**

**4/9/14**

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported

Resample in 3-4 months or 2500 hours

**031508424**

**3/5/15**

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported

Resample in 3-4 months or 2500 hours

**021603597**

**2/2/16**

All wear metals, moisture and oil acid number are in satisfactory ranges for this model unit and the running time reported.

Resample in 3-4 months or 2500 hours.

**021803722**

**2/8/18**

Moisture level is high which may be due to contamination in transit or the hygroscopic nature of this oil type (if using POE).

All wear metals and acid number are in satisfactory ranges for the model unit and the running time reported.

Resample in 3-4 months or 2500 hours



TRANE

Trane Chemical Laboratory

ENGINEERED COOLING SERVICES

2801 N DAVIS HWY

PENSACOLA, FL 32503

Phone Number:

# Oil Analysis

Lab Number:  
021803722

Served By:  
ENGINEERED COOLING SERVICES

Purchase Order:  
20202


Serial Number:  
SBNM245900

Equipment Owner:  
ESCAMBIA COUNTY


Location:  
BLANCHARD/CH-4

Model:  
YKFB 800


## Moisture



## Acid



## Tin



## Zinc

