

**PURCHASING  
AND MATERIALS  
MANAGEMENT**



**City of Myrtle Beach  
SOUTH CAROLINA**

**(843) 918-2170  
FAX: (843) 918-2182  
www.cityofmyrtlebeach.com**

**Addendum #02**

**March 3, 2022**

**IFB 22-B0033**

**Storage Building and Concrete Pad**

The purpose of this Addendum #02 to IFB 22-B0033 for Storage Building and Concrete Pad, dated February 8, 2022, and previously amended on February 17, 2022, is to answer the following questions:

1. What is the required R-value for the roof insulation?

**The roof insulation should be R-17.**

2. Should gutters and downspouts be provided?

**No, gutters and downspouts should not be provided.**

3. What is the desired roof slope?

**The desired roof slope is standard A-frame.**

4. Are any material testing or special inspections required?

**The building and concrete must be per the engineer drawings that the contractor must provide. All parts of the building must be constructed per City building codes.**

5. Is builders risk insurance required for the project? If yes, will the City provide that insurance?

**Builders risk insurance is required for the project; and yes, the City will provide the builders risk insurance.**

Sealed bids are due no later than Tuesday, March 8, 2022 at 2:00PM (local time.) No electronic bids will be accepted. The City is not responsible for late or misdirected mail.

Thank you,  
City of Myrtle Beach  
Ann Sowers  
Purchasing Office/Buyer  
Email: [asowers@cityofmyrtlebeach.com](mailto:asowers@cityofmyrtlebeach.com)