

	<h1>City of Wilson, NC.</h1> <h2>Addendum 1</h2>
<p><u>Please send inquiries and questions about this RFP to:</u></p>	<p>RFP: 2023-72 – Demolition Services – 300 Pender St. S.</p>
<p>Ricky Wilson</p>	<p>RFP Due Date: 4/11/2024 @ 2:00 pm</p>
<p>Purchasing Manager rvwilson@wilsonnc.org</p>	<p>Contract Type: Demolition Services</p>

Failure to acknowledge and return this addendum may subject your bid to be rejected based on the below information.

Vendor: _____

Question 1: Does the contractor need to remove any sidewalks? Yes, the contractor will need to remove any sidewalks on the property with the exception of the public sidewalks running parallel to Pender St., they are to remain in place.

Question 2: Do the wheel stops in the gravel parking lot need to be removed by the contractor? Yes, all wheel stops will need to be removed by the contractor for this project.

Question 3: Do the basketball courts get removed by the contractor? Yes, the concrete pad courts, steel/metal goal posts, and benches are to be removed by the contractor. Our parks and rec department will be removing the backboards and rims from the goal posts.

Question 4: Does the fencing get removed by the contractor? Yes, any fencing on the property is to be removed by the contractor, this includes the fencing around the HVAC unit and fencing running parallel to Gay St. on the property.

Question 5: There are two large tree stumps located behind the building, do they get removed by the contractor? Yes, the two large tree stumps are to be removed and backfilled with clean fill dirt by the contractor.

Question 6: Do the shrubs around the building get removed by the contractor? Yes, any shrubbery, flower beds, bed borders, etc. are to be removed by the contractor. Any outlying trees do not get removed.

Question 7: Does the gravel parking lot get removed by the contractor? No, we are leaving the gravel parking lot in place, the wheel stops in the parking lot are to be removed by the contractor.

Question 8: Do the street light posts on the property get removed by the contractor? No, our Electric department will be removing any poles, lighting, and wiring on the posts.