



## ADDENDUM NO. 2

Issue Date: July 8, 2022  
Project Name: West Wabasso Septic to Sewer Phase 3  
Bid Number: 2022050  
Bid Opening Date: **August 12, 2022 (UPDATED)**

This addendum is being released to extend the Bid Opening Date and answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

### Questions and Answers

1. Please confirm that the required warranties under section 02635 for the Submersible Wastewater Pumping Station from the approved manufacturers for the pump and GML Coatings come with a complete labor and material/parts warranty for the periods specified, and that the Bidder Contractor warranty does not need to extend beyond the standard one-year period for those items. **The warranties as listed in the bid contract are required. They are as follows:**

**Submersible Pump – 5 years**  
**GML Coating – 10 years**  
**Pipes and manholes – 1 year**