



STUDIO
FOUR
DESIGN

ADDENDUM 1 NOTIFICATION

To: Bidders of Record

Project: Etowah Carnegie Library Interior Accessible Lift

Date: 12/15/16

From: Paul Haskew

This Addendum forms a part of the Contract Documents for Etowah Carnegie Library Interior Accessible Lift and modifies the original Project Manual and Drawings dated 11/17/16.

General

Item 1 -

Bidder Questions

1. What is the desired finishes?

Answer; *Walls (lobby): Gyp Board - paint to match existing.*

Walls (shaft interior): Gyp Board - paint white.

Ceilings: ACT - match existing.

Base: Wood - paint to match existing.

Trim: Wood - paint to match existing.

Doors & Frames: Paint to match existing.

2. Are the frames, doors and hardware for doors 100 and 200 to be provided by the lift manufacturer?

Answer: *No, the contractor is to provide and coordinate with lift manufacturer.*

End Addenda

four14 Clinch Avenue
Knoxville TN 37902

865.523.5001
studiofourdesign.com

DESIGN MATTERS