

---

**SECTION 6 – ADDENDUM NO. 1**

NOTICE is hereby given that the Bidding Documents have been modified and replacement pages issued herewith. Replacement pages have an Issue Date of April 14, 2021, note “Rev. 01” in the header, and indicate text changes for additions by ***bold italic*** and deletions by ~~strikeout~~.

Replacement pages included:

- Table of Contents
- Section 1 – Invitation to Bid (*Page 1 only*)


Replacement drawings included:

- NONE

**BIDDERS ARE REQUESTED TO CONFIRM RECEIPT OF THE ELECTRONIC FILES VIA RETURN EMAIL.**

Issued by:

**Patterson and Dewar Engineers, Inc.**



Jack C. Wallace, PE  
Principal Engineer  
[jwallace@pdengineers.com](mailto:jwallace@pdengineers.com)

TN PE License #116746

## TABLE OF CONTENTS

Section 1 - Invitation to Bid

Section 2 - General Requirements

Section 3 - Terms and Conditions

Section 4 - Technical Specification – 69kV Power Transformer

Section 5 - Bid Form

Section 6 - **Addenda**

Exhibit A – Power Transformer Tank, Arrestor, and Neutral Grounding Details

Exhibit B – Power Transformer Communication

Exhibit C – Transformer Monitor Input Map

Exhibit D – Standard Transformer Information System (non-LTC)

Exhibit E – Standard Transformer Information System (LTC)

## REVISION HISTORY

<b>Rev. No.</b>	<b>Date</b>	<b>Description</b>
00	04/05/2021	Issued for bid
<b>01</b>	<b>04/14/2021</b>	<b>Issued for Addendum No. 1</b>

## SECTION 1 – INVITATION TO BID

### 1.01 PARTIES TO CONTRACT

- A. Buyer: City of Springfield  
405 North Main Street, Springfield, TN 37172  
Attention: Steve Sax  
Phone: (615) 384-6770 Email: [Steve.Sax@springfieldtn.gov](mailto:Steve.Sax@springfieldtn.gov)
- B. Engineer: Patterson & Dewar Engineers, Inc.  
1531 Hunt Club Blvd, Suite 200, Gallatin, TN 37066  
Attention: Jack Wallace, PE  
Phone: (615) 527-7078 Email: [jwallace@pdengineers.com](mailto:jwallace@pdengineers.com)

### 1.02 BID ITEM

- A. Buyer invites Bidder (Seller) to submit quotation for furnishing the following equipment (Goods):
- Bid Item A: one 69-13.2kV 18/24/30//33.6 MVA power transformer without LTC
  - Bid Item B: one 69-13.2kV 18/24/30//33.6 MVA power transformer with LTC
- B. Buyer will award contract for either Bid Item A or Bid Item B (not both).
- C. The contract generally consists of furnishing Goods with 5-year warranty, one set of spare parts, delivery to the Point of Destination, testing, offloading and assembling Goods, and certification that Goods are ready for energizing.

### 1.03 POINT OF DESTINATION

Wartrace Substation: Intersection of Bill Jones Industrial Dr. & Kelton Jackson Rd, Springfield, TN 37172.

### 1.04 BID SUBMITTAL

- A. Bids will be accepted until **2:00 pm on ~~April 27, 2021~~ May 4, 2021**. Electronic submittal of proposals is prohibited. Submit one hard copy of bid to:
- City of Springfield  
405 North Main Street, Springfield, TN 37172  
Attention: Lisa Crockett, *City Recorder*
- B. Seller's proposal shall be clearly marked as "**Bid for Wartrace Substation**" on the exterior of the mailing package.
- C. Seller shall submit proposal that will remain valid for a period of sixty (60) days after the date set for opening of bids.
- D. No bid security will be required to accompany bids.

### 1.05 DELIVERY AND PRICING

- A. Deliver Goods and offload to substation pad by **December 31, 2021**. Field services and assembly shall be completed **within 30 calendar days** of delivery of Goods. Seller shall quote best delivery date that is as close as possible to the requested delivery time.
- B. Seller is responsible for delivering and offloading onto Buyer-furnished pad. Seller is responsible for visiting Point of Destination to confirm accessibility prior to submitting a proposal. Buyer will not consider adjustments to the Contract Price after award due to Seller's failure to recognize the conditions under which Work is to be performed.