June 17, 2024

To: All Bidders/Plan Holders

Re: **Addendum No. 1**
        Public Works Bid No. 2024-005
        E 10th Street CBC Remediation

Addendum Number 1 is issued to provide changes and/or clarifications to the questions asked on the above referenced bid. Date, Time, and Location of submitting this bid remains unchanged.

General:
Questions and responses requesting plan clarification.

Question 1 – Will a GF-4 be acceptable for the CBC Repair/Remediation work?

Response 1 – A GF-4 WILL BE ACCECPTABLE FOR THE CBC REPAIR/REMEDIATION WORK.

Question 2 – The bid schedule shows the estimated quantities for Minor Paving and subgrade prep as 187 SY and drawings show the quantities as 377. Can you verify which number we are using?

Response 2 – 377 SY WILL BE THE QUANTITY USED FOR MINOR PAVING AND SUBGRADE PREP

Attachments:

Bid Documents & Specifications:
Section 3 – Revised Bid Schedule

ITEM NO.	APPROX. QTY.	CONSTRUCTION ITEMS	AMOUNT OF BID
1	377	Square Yard Subgrade Preparation, as specified and/or shown on the construction documents, complete in place, and accepted by the Owner.	$_____
4	377	Square Yards Minor Paving Type II, HMA SP-IV as specified and/or shown on the construction documents, complete in place, and accepted by the Owner.	$_____

Construction Plans:

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made part of the Contract Documents to the same extent as though contained in the original documents and itemized listings thereof.

Each bidder is required to acknowledge receipt of each addendum in Section 3 Bid Form. Failure to do so could render the bid non-responsive.

Plan Holders: As a courtesy, please fill out the information below and fax or email this page back to the City of Alamogordo, Attention: Barbara Pyeatt, Chief Procurement Officer at 575-439-4117 or bpyeatt@ci.alamogordo.nm.us.

Received By (Company): _____

Date Received: _____

Number of Sheets Received: _____   Time Received: _____

Signature: _____