



## Jackson County Board of Commissioners

67 Athens Street  
Jefferson, Georgia 30549  
Phone: (706) 367-6309  
Fax: (706) 708-2505  
Email: [myarbrough@jacksoncountygov.com](mailto:myarbrough@jacksoncountygov.com)

Date: August 2, 2021

To: Generator Companies

From: Myrna Yarbrough, Purchasing Manager

**RE: Addendum 2 to Jackson County ITB 210017, Furnish and Install Generator at JCCI**

1. Addendum 2 is hereby issued to questions. Breaker size on generator is larger than normal size for a 100% rated breaker. Specs call for a 600 amp and the generator is only good for 450 amp, normal size is 500 amp – Answer: 600 amp as indicated on the drawings – regular breaker with aux contacts as indicated on the drawings. Generator enclosure spec is aluminum. Can steel be used in place? Yes
2. All other terms and conditions in ITB 210017 remain unchanged.
3. Any inquiries concerning Addendum 2 should be made to Myrna Yarbrough, Purchasing Manager, (706) 367-6309 or via email at [myarbrough@jacksoncountygov.com](mailto:myarbrough@jacksoncountygov.com)
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing “Acknowledge Addenda #2” at bottom of the proposal.