

ADDENDUM NO. 1

BID NO: 164536

DATE OF BID OPENING: February 21, 2018

TIME: 2:00 PM

DEPARTMENT: Waste Resources

COMMODITY: Coated Pipe and Fittings

**Revised Specifications and Rescheduled Bid Opening**

**The specifications have been revised regarding joints on larger pipe sizes (30" and larger). Additionally, the bid opening date is rescheduled to February 21, 2018 at 2:00 PM.**

(SIGNED) \_\_\_\_\_

COMPANY: \_\_\_\_\_

PLEASE SIGN ONE (1) COPY OF ADDENDUM AND RETURN TO THE PURCHASING DEPARTMENT ([ghipp@chattanooga.gov](mailto:ghipp@chattanooga.gov) or fax to 423-643-7244 or mail to Purchasing (Attn: Geoffrey Hipp), 101 E. 11<sup>th</sup> St., Chattanooga, TN 37402). RETAIN A COPY FOR YOUR FILES.

**SPECIFICATIONS FOR PURCHASE OF  
PIPE AND FITTINGS FOR MOCCASIN BEND WASTEWATER SYSTEM  
EMERGENCY REPAIR STOCK  
CHATTANOOGA TENNESSEE  
December 2017**

**GENERAL INFORMATION**

This specification is for the purchase of spare pipe and fittings for use at the Moccasin Bend Wastewater Treatment System. The Plant is located at 455 Moccasin Bend Road, Chattanooga, Tennessee 37405.

**SPECIFICATIONS GENERAL**

All ductile iron pipe shall be Class 250 DI pipe. 14", 16", 20" and 24" pipe shall be push on type joints with locking gaskets. Standard push on gaskets will not be accepted. 30", 42", 48" and 54" shall be boltless restrained joint type pipe. Acceptable brand names are U.S. Pipe TR Flex, and American Pipe Flex-Ring. Any pipe not listed by trademark name shall be submitted for approval prior to acceptance. All Pipe and gasket specifications shall be included in all bid packages. Pipe shall be lined internally with a coating resistant to standard sanitary sewer contaminants including hydrogen sulfide corrosion and sulfuric acid corrosion. The material specified will be stored outside under cover, a minimum 3 year warranty shall be provided on the coating when stored in these conditions. Acceptable coatings are Ceramapure PL90 by Induron Protective Coatings, Permox, Tenemec 431 or equal. Coating specifications shall be included in all bid packages. Any coating not listed by trademark name shall be submitted for approval with the bid package and Vendor shall wait for written approval on submitted coating prior to the application of coating on any material supplied for this bid.

All ductile iron fittings shall be MJ and coated same as pipe. Sleeves shall be long pattern. Mega lugs must be EBAA Iron.

All PVC pipe shall be C900 DR18.

Freight to 455 Moccasin Bend Road site shall be included in the bid

Vendor shall coordinate delivery time with Moccasin Bend warehouse personnel and shall include all shipping costs.