



St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: March 28, 2022

TO: Prospective Respondents

FROM: Amy Lucey, Procurement Specialist

SUBJECT: Addendum #1 to Quote Request, # 37728, Install new 60-inch Aluminum Flap Gate on S-259 Discharge Pipe

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

- Q1: Our material vendor wishes to know about any **Line Pressure Information** for the existing HDPE pipe. Would it be possible to provide said information?
- A1: The line is not under pressure, the water bodies on both sides are at the same elevation. It is estimated that under pumping conditions (with both flap gates installed), the head on the upstream side would be less than 2-feet

NOTE: The Quote Due Date **remains** 2:00 p.m., **Thursday, April 21, 2022**

Please acknowledge receipt of this Addendum on the Quote FORM provided in the proposal package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.