



ADDENDUM NO. 1

Issue Date: June 25, 2024

Project Name: Trans Florida Rail Trail Boardwalk Repairs 2

Bid Number: 2024056

Bid Opening Date: July 11, 2024

This addendum is being released to answer questions received to date and to modify bid documents.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid may be declared non-responsive.**

Modifications to Bid Documents:

Updated Bid Form

Attachments:

Addendum 1 Bid Form

Questions and Answers

1. Regarding the project license requirements, are Certified Building Contractors eligible for bidding?
Yes.
2. Does the project currently have an estimated mobilization and completion date?
The mobilization and completion date would depend on when the Board approves and the permitting process.
3. How wide does the asphalt transition from the boardwalk to the trail need to be?
At least two feet.

Bid Form

Project Name: Trans Florida Rail Trail Boardwalk Repairs (2)

Bid #: 2024056
 Bid Opening Date and Time: July 11, 2024 2:00 P.M.
 Bid Opening Location: Purchasing Division
 1800 27th Street
 Vero Beach, FL 32960

The following addenda are hereby acknowledged:

Addendum Number	Date
_____	_____
_____	_____
_____	_____

In accordance with all terms, conditions, specifications, and requirements, the Bidder offers the following:

Item – Standard Decking			Total
1. Boardwalk #1 repairs			\$
2. Boardwalk #2 repairs			\$
3. Permits			\$
Siderail replacement (if needed)	Quantity 160	Unit Price \$/LF	\$
Stringers 2X12 (if needed)	200	\$/LF	\$
Pilings 6X6 (if needed)	100	\$/LF	\$
Railing Posts 4X4 (if needed)	60	\$/LF	\$
Total			\$

Alternative – Non Slip		Total
1. Boardwalk #1 repairs		\$
2. Boardwalk #2 repairs		\$
Total		\$