



RFI Response

To: Bidders
From: Bryan Harrell
Date: April 18, 2023

Job Name: Comfort Station
WAS Job #: ENGR-041823
Job Phase: BID

Re: Comfort Station - RFI Questions/Responses

- 1) Provide information on the mop sink and valve.
 - a) Composite mop sink integral 3" drain; Z1996-SF service faucet with pale hook, -SDL drain, strainer & lint basket, -MH mop hanger, -HH hose & bracket, -BV vinyl bumper guards, -WG SS wall guard. Coordinate with general contractor to ensure that 2" thick blocking is provided in wall for faucet Mounting. 140 degrees fahrenheit water temp. connections: CW ½", HW ½", waste 3", vent 2".
- 2) What kind of water closet is intended?
 - a) Water closet to match spec on P100.