

 Lexington County School District Two	Lexington County School District Two	AMENDMENT #1 Date of Amendment: June 12, 2019	
LEXINGTON COUNTY SCHOOL DISTRICT TWO PROCUREMENT SERVICES 715 NINTH STREET WEST COLUMBIA, SC 29169	Procurement Official	William A. Shealy Director of Procurement	
	Phone	(803) 739-4057	
	E-Mail Address	tshealy@lex2.org	

AMENDED SOLICITATION #	19-026-B
-------------------------------	-----------------

**INVITATION FOR BIDS
(IFB)**

DESCRIPTION	Paving Project at Community Education Center
-------------	---

NAME OF OFFEROR:	
AUTHORIZED SIGNATURE:	
TITLE	
PRINTED NAME:	DATE SIGNED

SEE AMENDMENTS TO SOLICITATION ON PAGE 2

AMENDMENTS TO SOLICITATION (JAN 2004): (a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: www.lex2.org (b) Offerors shall acknowledge receipt of any amendment to this solicitation (1) by signing and returning the amendment, (2) by identifying the amendment number and date in the space provided for this purpose on Page Two of the original solicitation, (3) by letter, or (4) by submitting a bid that indicates in some way that the bidder received the amendment. (c) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

QUESTIONS FROM OFFERORS - AMENDMENT (JUN 2017)

The solicitation is amended as provided herein. Information or changes resulting from questions will be shown in a question-and-answer format. Questions received have been reprinted below. The "District's response" should be read without reference to the questions. The questions are included solely to provide a cross-reference to the potential offeror that submitted the question. Questions do not form a part of the contract; the "District's response" does. Any restatement of part or all of an existing provision of the solicitation in an answer does not modify the original provision.

THE FOLLOWING INFORMATION SHALL BE INCORPORATED AS PART OF THIS SOLICITATION:

The Bidding Schedule has been revised! The Lump Sum Bid Form (Bidding Schedule Page 1) has been revised. You must submit this revised form.

ALTERNATE #1: As an alternate, in lieu of asphalt paving section, provide cost that includes concrete pavement section. The concrete pavement section will be minimum 5" of Portland Cement Concrete over 6" compacted Macadam Base Course. The pavement section in the right-of-way shall remain as the plans indicate. Portland cement concrete should conform to Section 501 of the SCDOT Standard Specifications and have a minimum flexural strength of 550 psi and compressive strength of 4,000 psi. Portland cement concrete pavement should contain about 5 to 7 percent entrained air and should have a maximum water to cement ratio of about 0.45. A maximum slump of 4" should be used for non-slip formed placement, and 2" for slip formed placement. A 15' maximum joint spacing shall be used and laid out as square as possible. The concrete pavement section should be reinforced with 6" x 12", D5 x D3 deformed welded wire fabric, with heavier steel in the longitudinal direction. The wire fabric should be placed just slightly above the mid-depth of the slab.

Please provide a unit cost for 400 CY of compacted macadam stone.

Bid Bond is required

Performance and Payment Bonds, each in the amount equal to 100% of the contract price, shall be required of the successful bidder. **This requirement will be waived if the total awarded amount is less than \$50,000.00**

THE OPENING DATE REMAINS THE SAME!

ALL OTHER TERMS & CONDITIONS REMAIN THE SAME!

VIII. BIDDING SCHEDULE

SOLICITATION #19-026-B
PAVING PROJECT AT COMMUNITY EDUCATION CENTER
LUMP SUM BID:
(PAGE 1 OF 2)
REVISED

BID SUBMITTED BY:	(Contractor's Name)
BID SUBMITTED TO:	Lexington County School District Two (Owner)
FOR PROJECT:	Paving Project at Community Education Center
PROJECT #:	19-026-B

BASE BID AGREEMENT: The undersigned, having examined all the Bidding Documents and acknowledging all addenda as follows:

ADDENDUM(S) # _____

Shall execute the entire Work in the Bidding Documents as the base bid for the lump sum of:
\$ _____ which sum is hereby called the **BASE BID**.

ALTERNATE TO THE BASE BID:

(1) *ALTERNATE #1:* Add/Subtract for concrete in lieu of asphalt

ADD TO BASE BID **\$** _____

OR

(DEDUCT) FROM BASE BID **\$**(_____)_____

UNIT COST FOR 400 CY OF COMPACTED MACADAM STONE **\$** _____

BID SECURITY: The bidder encloses bid security in the amount of not less than five (5%) percent of the BASE BID.

VIII. BIDDING SCHEDULE (CONT)

**SOLICITATION #19-026-B
PAVING PROJECT AT COMMUNITY EDUCATION CENTER
LUMP SUM BID:
(PAGE 2 OF 2)
REVISED**

CONTRACTOR'S CLASSIFICATIONS AND SUBCLASSIFICATIONS WITH LIMITATION:

FEDERAL IDENTIFICATION NUMBER: _____

SC CONTRACTOR'S LICENSE NUMBER(S): _____

CLASSIFICATION & LIMITS: _____

SUBCLASSIFICATION(S) & LIMITS: _____

AUTHORIZATION:

CONTRACTOR'S LEGAL NAME: _____

ADDRESS: _____

CITY, STATE & ZIP: _____

TELEPHONE: _____ EMAIL: _____

PRINT NAME: _____ TITLE: _____

SIGNATURE: _____ DATE: _____