

April 14, 2022

**ADDENDUM TO ADVERTISED CONTRACT**

**PROJECT NAME:** CITY OF HOLLY SPRINGS HOLLY SPRINGS  
PARKWAY WIDENING PROJECT PH II

**PROJECT NUMBER:** 2022-02

**CITY:** CITY OF HOLLY SPRINGS

**AMENDMENT NUMBER:** 1

**LETTING DATE:** APRIL 28, 2022

THE FOLLOWING CHANGES ARE HEREBY MADE TO THIS CONTRACT. THE BIDDER IS RESPONSIBLE FOR MAKING ANY NECESSARY CHANGES IN INK IN THE PROPOSAL. BIDDER SHALL ACKNOWLEDGE THIS AMENDMENT BY CHECKING THE APPROPRIATE SPACE ON THE AMENDMENT CERTIFICATION PAGE.

.....

**QUESTIONS/CLARIFICATIONS**

1. Please note the correct RFB # on the Bid Documents Cover page is RFB#2022-02.
2. The signing and marking plans show 6” striping for all longlines, however; the pay items included in the bid form are for 5”. Which will be used? **5” Thermo will be used**
3. What are the work hours and days for the project? **Work hours are Monday – Friday from 8am – 5 pm. Weekend work will be permitted with prior written approval from the City of Holly Springs.**
4. Are there any lane closure restriction times for flagging or pacing traffic? **No lane closures before 9 am nor after 4pm Monday thru Friday.**
5. With the Utility Adjustments possibly taking up to 170 days after NTP (as per the general conditions), will the County please extend the completion time to 18 months? **AGL’s high pressure steel main is to be relocated along the entire project limits on the eastern side of the roadway. At a minimum the clearing, the right shoulder, and the culvert extension will need to be completed on the east side of the road before AGL will have a place for the gas line to be relocated to. So, there will be some concurrent activities that will have to take place to achieve the 12 month schedule.**
6. Will the County please verify that since all work is to be performed in accordance with the latest GDOT specifications and provisions, that SP 109 - AC Index will

- be used on this project? **The Asphalt Index special provision will be applicable to this project.**
7. Do not find any specific bid bond format requirement, I believe STD bid bond AIA document A310 will be acceptable. **The standard AIA Bid Bond form is acceptable.**
  8. Probable earliest bid award date. **Notice to Proceed is anticipated in mid-June 2022.**