



**ADDENDUM # 1
FOR
RFP # 2017-46**

**GENERATOR PREVENTATIVE MAINTENANCE AND AS NEEDED/ON CALL
REPAIR SERVICES**

This addendum is being issued to announce, clarify and address questions or certain issues that have risen since the RFP was originally issued. All contents of this addendum shall be incorporated into the solicitation documents and the ensuing contract with the awarded Firm. Firms submitting proposals shall acknowledge and include this addendum within their submittal. Addendum, Proposal Form and General Conditions Worksheet shall not be altered and completed in their entirety.

QUESTIONS AND ANSWERS:

Question # 1 – Do technicians need to have Kohler and Caterpillar certifications.?

Answer # 1 – This would be preferred however a certification in diesel mechanics will be acceptable for techs.

Question # 2 – Provide two contact phone numbers. The phones shall be answered by actual persons and not recorded messages?

Answer # 2 – A 24 hour service is acceptable. The point is that a real person will respond to the emergency phone call.

Question # 3 – Fuel filters and fluid filters such as oil will be changed twice a year?

Answer # 3 – Fuel filters and all fluid filters will be change a minimum of once a year with the major service.

Question # 4 – Air filters on an as needed basis?

Answer # 4 Air filters once a year with major service

Question #5 Dedicate a minimum of 8 hours for service

Answer #5 This is to mean that the service needs to be completed in a minimum of eight(8) hours, completed in less is acceptable.

Question# 6 Fuel sample once a year.?

Answer #6 Yes a fuel sample once a year sent to a lab with the major service.

Question #7 Anti-freeze test?

Answer #7 Anti-freeze test once a year, a strip test is ok.

Here is the corrected info on the generators:

**Public works Caterpillar
Model D50-4s
s/n CAT00C44KNCD00810
50KW
Cat engine s/n E4M01519**

**Bluffton Law enforcement center
Kohler
Model 100REOZJE
s/n 2319339
100kw
John Deere Engine s/n PE4045L143981**

**NOTE!
Please follow the instructions in section 5 of the RFP. "SUBMITTALS AND FORMAT"
This is important.**

The proposal due date still remains the same. Sealed proposals will be received by the Town of Bluffton (Attn: Ron Olson) at 20 Bridge Street, Bluffton, South Carolina, 29910 until 2:00 p.m. on April 6, 2017.

**ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED
RECEIPT OF THIS ADDENDMU IS HEREBY ACKNOWLEDGED**

NAME OF BUSINESS

BY: _____
SIGNATURE

NAME AND TITLE

MAILING ADDRESS