

**PURCHASING
AND MATERIALS
MANAGEMENT**



**City of Myrtle Beach
SOUTH CAROLINA**

(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com

Addendum #02

August 6, 2021

RFP 22-R0005

Fire Alarm Inspection, Testing, and Repair

The purpose of this Addendum #02 to RFP 22-R0005 for Fire Alarm Inspection, Testing, and Repair, dated July 21, 2021, and previously amended on July 29, 2021, is to answer the following question:

1. Will the Offeror be responsible for any fire alarm equipment in the elevator pit at TicketReturn.com Field, or is that left to the elevator inspectors? If the Offeror will be responsible for the fire alarm equipment in the elevator pit at TicketReturn.com Field, must the Offeror provide someone to help access the pit?

Yes, the Offeror will be responsible for the smoke detector at the top of the elevator shaft at TicketReturn.com Field. The Offeror will need to coordinate with the TicketReturn.com Field staff and with Otis Elevator during the off-season to accomplish this task.

Sealed proposals are due no later than Thursday, August 12, 2021 at 2:00PM (local time.) No electronic submissions will be accepted. The City is not responsible for late or misdirected mail.

Thank you,
City of Myrtle Beach
Ann Sowers
Purchasing Office/Buyer
Email: asowers@cityofmyrtlebeach.com