



2

## **ADDENDUM # 1**

### **SOLICITATION IFB # 2021-03**

### **LEC Parking Expansion - Redesign**

This addendum is being issued answer questions and provide the link to the online bid opening.

All contents of this addendum shall be incorporated into the solicitation documents and the ensuing contract with the awarded Contractor. It is the Contractor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid response. Acknowledgement may be confirmed by noting the total number of addenda on the Signatory Sheet (e.g. Addenda 1 of 1). Failure of a Contractor to acknowledge each addendum may prevent the bid from being considered for award and deem the Contractor as non-responsive.

#### **Link to online bid opening**

Remember that bid packages are to be PDFd (including any bonds) and uploaded to the Vendor Registry site in accordance with instructions contained in the solicitation. Vendor Registry will not permit any bids to be submitted after the deadline.

Use the link below to join the Zoom meeting for the bid opening. The Town will show the Vendor Registry portal to show bids submitted timely and will announce the names and the bid totals.

<https://townofbluffton.zoom.us/j/96040700804?pwd=UGk1VWwhYMHFNjdjFyKzNabUVnU292Zz09>

Meeting ID: 960 4070 0804

Passcode: 553504

One tap mobile

#### **Question and Answer**

1. Can the Town provide a bid sheet in Excel?  
Yes, see attached.
2. The Town notes that the unsuitable quantity allowance has been adjusted to match the impervious area.  
Please use Excel bid sheet for your bids.
3. Do contractors need to acknowledge the previous Q&A.  
No, the previous Q&A has been incorporated into the current solicitation, therefore any contractor who submits a bid acknowledges all information contained therein. Contractors only need to acknowledge addenda to the solicitation.

4. Can the Town provide additional information around the conduit routing?

Please see the Palmetto Electric plan and the attached PDFs of the approximate routing of the conduit. The utility plan provided in plan set, combined with the Palmetto Electric plans now attached, and the proposed routing map provide the best information for conduit locations, amounts and sizes at this time. Plan sheets are subject to change as final construction drawings are finalized. The successful bidder is responsible for installing the conduit and pull boxes in accordance with the plans and specifications. Building penetrations, poles, pulling of wire and data cable, and connections are the responsibility of others. The previous statement does not apply to the gates and associated equipment required to make the gates functional.

**All prospective Respondents are reminded and hereby instructed not to contact any member of the Town of Bluffton Council, Town Manager or Town of Bluffton staff members, other than the noted contact person OR the Town's Purchasing Administrator regarding this solicitation or their response at any time during the solicitation and award process. Any such contact may be cause for rejection of your submittal.**