

- Inspect the vent
- Inspect the vent screen and replace if necessary
- Inspect the upper hatch
- Inspect the upper hatch gasket and replace if necessary
- Inspect the aviation light and replace standard bulbs, once a year, during the inspection
- Inspect the antennas and cables that are attached to the tower
- Inspect the catwalk and catwalk railing
- Inspect the exterior coatings

A. Wet Interior Cleaning and Inspection shall include:

- Removal of all accumulated material from the interior of the tank
- Inspection of the interior surfaces including coatings
- Disinfection of the tank interior in accordance with AWWA C-652-11 Chlorination Method II, as required

4. REPORTING

A written report, along with an electronic copy, shall be prepared for each tank and furnished to the City upon completion of the inspection. The reports should include written documentation of the inspection along with color photos of the primary components of the structure as well as any defect encountered during the inspection. Video documentation alone, without a written report, will not meet the reporting requirements.

5. MISCELLANEOUS

In the event the tank must be drained to facilitate cleaning and inspection, the Contractor shall be responsible for providing pressure relief valves and/or pressure vessels as required to maintain appropriate pressure in the system.

6. SCHEDULE OF WORK

All inspections and cleaning should be scheduled between the hours of 7:00 am and 5:00 pm., Monday through Thursday. Modification of these times will be considered in emergency or unforeseen situations.

7. PAYMENT

Payment for the Program shall be in equal annual amounts for each tank. Payments will be due upon completion of the inspections and delivery of the written reports.