

ADDENDUM No. 6

MBWWTP SOLIDS PROCESS OPTIMIZATION IMPLEMENTATION PHASE 2 THICKENER UPGRADES CONTRACT NUMBER W-16-017-201

CITY OF CHATTANOOGA, TENNESSEE

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

1. **Contractor Question:** This project has some Variable Frequency Drives in it. In the specs it list as acceptable manufactures: Dan Foss, General Electric, Fuji. It does not list Square D Company/Schneider-Electric. We have furnished several VFD to City of Chattanooga, Moccasin Bend projects over the last several years without incident. Please issue an addendum that our company is an acceptable manufacture also, I would greatly appreciate it. Normally, on your project if a VFD is located inside a Motor Control Center your specs will state "the VFD's located inside the MCC shall be the same as the MCC Manufacture".

Response: Schneider/Square D is approved for VFDs assuming their products meet the requirements of the specifications.

2. **Revise Specification 26 29 23 with the following:**

Part 2.01.A.: Add " 4. Schneider/Square D"

3. **Contractor Question:** In discussing the new "replacement items" for the Gravity Thickeners with the equipment vendors/manufacturers, it has become apparent that any "as-built" details or submittal drawings for the existing thickeners (1&2 and 3-5) would be beneficial. If available, please provide any "as-built" details or submittal drawings for the gravity thickeners.

Response: Original equipment vendor shop drawings are not available. The record drawings available do not show any more detail than what is already provided in regards to the thickener mechanisms, etc. Additional shop drawings and record drawings will not be provided.

March 2, 2018

/s/ Justin C. Holland, Administrator
City of Chattanooga
Department of Public Works