



**HOLSTON ENGINEERING, INC.**

301 Montgomery Street, Suite #4  
Johnson City, TN 37604  
(423) 926-5991 Voice; (423) 926-9119 Fax  
e-mail: [holsteng@usit.net](mailto:holsteng@usit.net)  
December 30, 2021

Ms. Michelle Ramey  
Assistant Purchasing Agent  
Sullivan County Purchasing Department  
3411 Hwy 126 Suite 201  
Blountville, TN 37617-0569

Re: Indian Springs Elementary School Roof Top Replacement Bid document addenda

Dear Michelle:

In response to questions asked during the pre-bid meeting and in subsequent emails Holston Engineering, Inc. is pleased to offer the following addenda letter to address any questions or concerns that have been generated during the bid process.

1. ME-01 is listed as a specification sheet on the cover sheet of the drawing package but is not included in the drawing set. Please clarify.
  - ME-01 was never generated as we have a specification book and is not needed for a complete job. Please consider the drawing ME-01 removed from the contract documents.
2. Please provide contact information for Fire Alarm Service provider. They will need to connect the return duct smoke detectors to the existing fire alarm system.
  - **Vendor for Indian Springs Fire Alarm**  
  
Johnson Controls Fire Protection  
5695 Bobby Hicks Highway  
Johnson City, TN. 37615  
865-203-7455  
email: [jennifer.yi.hanley@jci.com](mailto:jennifer.yi.hanley@jci.com)
3. Verify model number and brand of existing HVAC unit to ensure that proper roof curb adapter is provided.

- **Rooftop HVAC unit**  
Model#50TJQ008-501  
Brand- Carrier Unit

This letter will be shared via Drop Box to everyone that is currently on the bidders list.

If you have any questions, please feel free to contact me.

Sincerely,  
HOLSTON ENGINEERING, INC.



Derwin E. Cartmel, PE  
President

