



CITY OF CONROE

Est. 1904

City of Conroe
PO Box 3066
Conroe, Texas 77305

ADDENDUM NO. 3

DATE ISSUED October 13, 2020

PROJECT NAME: 1015-2020 Roof Replacement at Conroe Recreation Center

This revision shall be considered part of the contract documents for the above named project, and shall be incorporated integrally with the previously issued documents. Wherein provisions of the revisions differ from the provisions of the original documents and/or the provisions of previously issued addendum, the provisions of this revision shall govern and take precedence.

Clarification:

The contractor is responsible for providing all necessary engineering including stamped & sealed calculations and an engineer's evaluation of the existing structure. Contractor is responsible for obtaining all necessary information to provide evaluation.

Contractor will be responsible for all costs associated with any modifications to framing system as determined by their engineer. The framing system as detailed in the plans and scope of work are the minimum spacing requirements.

Roof hugger is an acceptable alternate on the basis that the contractor provides stamped sealed calculations and an engineer's evaluation of the existing building. The roof hugger alternate system is still required to include the specified insulation and cover board at both roof areas.

This is to be a turnkey project.

NOTE: This is the last addendum. Q&A is closed for this project.

Company Name _____



CITY OF CONROE

Est. 1904

By the signature affixed below, Addendum No. 1 is hereby incorporated into and made a part of the above referenced solicitation.

ACKNOWLEDGED

Authorized Signature

Printed Name

Respondent/Contractor

Date

Kristina Colville

Kristina Colville, Purchasing manager