

ADDENDUM #1
ADVANCED WATER METERING INFRASTRUCTURE SYTEM
REQUEST FOR PROPOSALS
CITY OF GATLINBURG - ISSUED SEPTEMBER 2019

Proposals Due: **October 17, 2019, 2:30 PM, EST**

Clarifications of Questions Through October 10, 2019:

1. Section A 5.6.4 – the customer web portal will be water and sewer only, this project does not include gas or electric.
2. Any replacement meter box lids needed for this project will be provided by the owner. The existing boxes and lids are primarily metal.
3. The meters 1” and smaller are installed in iron yokes with expansion wheels.
4. Meters larger than 1” are anticipated to be flanged.
5. Meter change-outs for this project are anticipated to be same-size.
6. Meters larger than 3” are typically in vaults.
7. The owner will perform meter box repairs related to line breaks, inoperable curb stop, broken box, etc.
8. Regarding the meter change-out process, the contractor shall provide:
 - a. Old meter number and old meter reading
 - b. New meter number, radio ID number and new meter reading
 - c. GPS location (sub-meter accuracy preferred) and picture of meter location
 - d. Information if location has water leak, inoperable curb stop, etc.
 - e. Other pertinent information as may be applicable.
9. There are no prevailing labor rates for this project.
10. The owner’s billing company is MuniBilling, Greensboro, NC. Any integration fees from the billing company related to this project will be borne directly by the owner.