

# Addendum 3

**City of Canton, Ohio**  
Purchasing Department  
218 Cleveland Ave. SW, 4<sup>th</sup> floor  
Canton, Ohio 44702

Car Park EV Charging Station Installation

---

**Item/Project**

Engineering Department

---

**Responsible Department**

May 1, 2020 at 2:00 PM local time

---

**Qualifications Due On or Before**

## Qualifications Submitted By:

---

**Company Name**

---

**Street Address**

---

**City**

**State**

**Zip**

---

**Contact Person**

**Phone No.**

**Email Address**

1. Providing new corrected E200 with corrected amperage (E200 Car Park Fulton Road Panel “A” shows the panel as a 250 A. Please strike 250 A and replace with 400 A. (480/277V, 3Ø, 4W., 250A MCB, 42kAIC, FULL CAPACITY NEUTRAL to be replaced with 480/277V, 3Ø, 4W., 400A MCB, 42kAIC, FULL CAPACITY NEUTRAL))

End of Addendum