

Fuel 2022-09 Q&A

1. Is the on site tank a temporary tank for your use in case your tank is not operational? Does the tank have to be a certain size?

Yes. The temporary tanks would need to be at least 1,000 gallon tank for gasoline and a 3,000 gallon tank for diesel. The tank that they will put the gasoline and/or diesel in, is already on-site and it is owned by the County. Vendors will need to pump off into those specific tanks. On-site could also mean, if we are out on a job and need fuel, that they would be able to come to us, where we are currently working.

2. Stand by Truck. Please clarify what that means? where specifically in the bid is this “stand by truck”? If it is #8 on page 3, that means “to have a tank or fuel tanker – on stand by for emergency issues