



ADDENDUM NO. 1

Issue Date: April 18, 2022

Project Name: Replacement of (3) Sodium Hypochlorite Storage Tanks

Bid Number: 2022047

Bid Opening Date: **May 10, 2022**

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. The addendum must be acknowledged where indicated on the bid form, or the bid may be declared non-responsive.

Questions and Answers

1. Who is the engineer of record for this project? **There is no Engineer of record for this project.**
2. What is the engineer's budget for this project? **\$120,000, turn key operation.**
3. Is there an original installation drawing, if so will the county provide a copy? **There are no drawings.**
4. Who do we contact to make arrangement for a site visit? **Plant phone number is 772-226-3225. Mike Wyatt is the Chief Operator.**
5. Please confirm that the specification should be amended to provide restraints on each tank rated for 180 MPH winds. **Restraints rated for 160 MPH winds are already available to use at the location.**
6. Please confirm that the specification should be amended to include a reverse sight-glass on each tank. **No sight-glass is needed.**