



Georgetown County, South Carolina

129 Screven Street, Suite 239
Post Office Drawer 421270
Georgetown, SC 29442-4200
(843) 545-3083 • Fax (843) 545-3500
E-Mail • purch@gtcounty.org
Website • <http://www.gtcounty.org>

ADDENDUM #6 TO BID #19-076

BID NUMBER: 19-076

ISSUE DATE: October 31, 2019

REVISED BID OPENING DATE: Wednesday, December 18, 2019 OPENING TIME: 3:30 PM (ET)

Bid Opening Location: Georgetown County Courthouse, Suite #239, (Purchasing Conference Room)

PROCUREMENT FOR: Leachate Management Upgrade

This addendum will amend **Bid #19-076, Leachate Management Upgrade** originally issued on October 31, 2019. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: www.gtcounty.org, select Quick Links, “Bid Opportunities” and “Current Bids.”

The following items are issued to add to, modify, and clarify the Bidding and Contract Documents. These items shall have full force and effect as the Bidding and Contract Documents, and cost involved shall be included in the bid prices. Bids, to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

IN THE SPECIFICATIONS

1. Section 00750 Summary Schedule and Key Milestones: Paragraph 1.03.C.; delete:

“Substantial Completion: 75 calendar days from Notice to Proceed

Final Completion: 90 calendar days from Notice to Proceed”

and replace with:

“Substantial Completion: 120 calendar days from Notice to Proceed

Final Completion: 135 calendar days from Notice to Proceed

If any part of the work cannot be accomplished as stated above, bidder shall describe that part of the work and provide a timeframe for completion in the Exceptions page of the bid.”

2. **Section 00300 – Bid Form – Replace with the attached bid form dated 12/09/19.**
3. **Section 01025 – Measurement and Payment – Delete Item 2 and replace with the following:**

“Item 2 – Tank Cleaning

1. The lump sum price bid for Tank Cleaning will be full compensation for all labor, materials, tools, equipment, supervision and incidentals required to perform cleaning of the existing leachate tank utilizing high-pressure washing equipment, including pumping of all leachate generated during cleaning to the existing leachate collection system manhole no. 2 and removal of any remaining solids for disposal in the landfill.”

4. **Page 153 of 184, Section 11185 – Blower Package, Part 1 – General 1.01 A.: Delete “20” and replace with “25.”**
5. **Page 166 of 189, Section 11311 – Leachate Transfer Pumps – Add the following paragraph:**

“ 2.07 Liquid Level Transmitter

A. Provide a submersible gauge pressure transducer design for long life use in harsh environments. All wetted materials shall be 316 stainless steel. Transducer shall include maintenance-free aneroid bellows for moisture protection and polyurethane jacketed cable. Transducer shall be manufactured by Geotech Environmental Equipment, Inc. 2650 East 40th Avenue, Denver, Colorado 80205 (303) 320-4764 • (800) 833-7958 • FAX (303) 322-7242 email: sales@geotechenv.com website: www.geotechenv.com

B. Provide system for slope riser pump lockout based on a high level in Leachate storage tank. System logic shall include a tank mounted float switch, Banner Engineering Receiver and Transmitter (or equal), and all necessary relays in the slope riser pump control panels to provide a functional “fail-safe” system. The system shall lockout the pumps in the event of tank float switch circuit failure, loss of radio communication, loss of power at the tank control panel, as well as a high level in the leachate storage tank. Radio panel shall be installed at cell 8 slope riser pump station and the signal shall be hardwired from there to the rest of the pump stations. Provide repeaters as necessary to provide a reliable signal for operation from the tank to the radio panel.”

ON THE DRAWINGS

1. On Sheet 1 – Delete the “General Construction Sequence” notes 1-13 in their entirety.
2. On Sheet 1 – Add the following:

LEACHATE MANAGEMENT NOTES

1. OWNER WILL DISCHARGE LEACHATE FROM THE LEACHATE TANK TO WITHIN ONE FOOT OF THE BOTTOM OF TANK PRIOR TO CONTRATOR’S NOTICE TO PRECEED.
2. A SECONDARY CONTAINMENT LINER SYSTEM IS IN PLACE WITHIN THE BERMS SURROUNDING THE LEACHATE TANK. CONTRACTOR SHALL BE RESPONSIBLE FOR ANY LEACHATE SPILLS DURING CONNECTION OF THE INFLUENT LINE MODIFICATIONS AND THE 4-INCH HDPE TANK BYPASS LINES. CONTRACTOR SHALL PUMP ANY LEACHATE THAT ACCUMULATES IN THE SECONDARY CONTAINMENT LINER SYSTEM TO THE EX. LEACHATE MANHOLE NO. 2.
3. ONCE THE TANK BYPASS LINE IS OPERATIONAL, CONTRACTOR SHALL PROVIDE TANK CLEANING SERVICES TO INCLUDE HIGH-PRESSURE WASHING THE INTERIOR OF THE TANK. LEACHATE GENERATED DURING TANK CLEANING SHALL BE PUMPED TO THE EX. LEACHATE MANHOLE NO. 2. ANY REMAINING SOLIDS SHALL BE REMOVED AND DISPOSED IN THE LANDFILL.
4. CONTRACTOR IS NOT REQUIRED TO PROVIDE A TANKER TRUCK DURING CONSTRUCTION AND WILL RATHER UTILIZE THE SECONDARY CONTAINMENT SYSTEM TO CAPTURE ANY INCIDENTAL LEACHATE SPILLS.

[THE REMAINDER OF THIS PAGE IS INTENTIONALLY LEFT BLANK]



ADDENDUM ACKNOWLEDGEMENT

Bid #19-076
Leachate Management Upgrade
Mandatory Submittal Form

To be returned with the final proposal submission to Georgetown County.

COMPANY NAME: _____

Addendum #1 Received Date: _____ Initialed By: _____

Addendum #2 Received Date: _____ Initialed By: _____

Addendum #3 Received Date: _____ Initialed By: _____

Addendum #4 Received Date: _____ Initialed By: _____

Addendum #5 Received Date: _____ Initialed By: _____

Addendum #6 Received Date: _____ Initialed By: _____

If your Bid submission has already been mailed, acknowledgment may be provided by faxing this form to (843)545-3500, or attaching a digital scan and sending by e-mail.

[THE REMAINDER OF THIS PAGE IS INTENTIONALLY LEFT BLANK]