

CLARIFICATION #1

DATE OF ISSUANCE: July 10, 2020

PROJECT: Portage – West Middle School – Storage Barn
7145 Moorsbridge Rd.
Portage, MI 49024

OWNER: Portage Public Schools

ARCHITECT'S PROJECT NO.: 19-220

ORIGINAL BID ISSUE DATE: May 18, 2020

CLARIFICATION

ELECTRICAL SCOPE

Plan C100 calls for 'electrical service for building by others prior to project'. What is the limit of this scope? E101 shows 'new underground feeder' which is presumed to be in relation to C100 service scope, but on the one line diagram on E1010, the complete service with notes about new Square D breaker in existing panel and underground conduit. Will this be the part that is by others?

Response:

the note on C100 is inaccurate, it should read "saw-cutting / trenching of the pavement for electrical work shall be by others", all electrical work shown in the E sheets is part of the project and will need to be included in the bid.

Answered By: MIKE GALOVAN, TOWERPINKSTER, PROJECT MANAGER Date: 7-10-2020