

**Indian River County
Purchasing Division
1800 27th Street
Vero Beach, FL 32960
Phone (772) 226-1416**



ADDENDUM NO. 3

Date: March 31, 2023

**Project Name: 66TH AVENUE ROADWAY WIDENING (69TH STREET TO CR510/ 85TH STREET),
FDOT FM No.: 436379-2-54-01 (TRIP)**

Bid Number: 2023016

Bid Opening Date: Wednesday, April 5, 2023 at 2:00 PM.

This addendum is released to provide answer/ questions received to date. All information provided herein is hereby incorporated into the bid documents.

The following questions have been received:

Question 1. There is a note in the plans that calls for all RCP to be class IV. Is that correct?

Answer 1. Yes.

Question 2. HDPE is shown for all outfalls. HDPE tends to float. Is this correct?

Answer 2. The pipe material shown on the plans is correct.

Question 3. The underdrain Placement detail on sheet 55A shows the invert of the underdrain at the same elevation as the 60" RCP. Is this correct??

Answer 3. Yes

*******This Addendum must be acknowledged with submittal package and/or
by return of this Acknowledgement with your submittal package *******

Company Name _____

Name: _____ **Title:** _____
(Type / Printed)

Authorized Signature: _____ **Date:** _____

Telephone: _____ **Email:** _____