



City of Milton
Purchasing Department

ITB 2020.01 Hamilton Bridge – Upgrade of water Distribution
ADDENDUM #3 – HDPE CHANGE
March 9, 2020

Prepared by KH&A
Project Number 2019 17

The following is a summary of the revisions made to the Construction Plans and Documents for the Hamilton Bridge Road Water Main Upgrade project. The Contractor is cautioned to review the Plans and Documents carefully to ensure all additions, deletions and revisions are incorporated into the work.

General:

Change HDPE SDR 9 to HDPE SDR 11 in plans.

End of Addendum #3

The information given in this addendum is in addition to or supersedes conflicting information in the invitation to bid and is hereby made a part of the request.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Amendment. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

BIDDERS MUST SIGN THE AMENDMENT AND SUBMIT IT WITH THEIR BID.

ACKNOWLEDGEMENT:

I hereby certify that I have received the above addendum:

Signature

Date

THIS ACKNOWLEDGEMENT MUST BE RETURNED WITH BID/PROPOSAL PACKAGE.