



1/16/2024

McWilliams Road Improvements  
**Addendum #2**

**NOTICE TO BIDDERS**

The following corrections, revisions, additions, and/or information for the above referenced project and shall be incorporated into the Plans, Specifications, and/or Contract Documents for the project as described below. The corrections, revisions, additions, and/or information shall henceforth be regarded as an integral part of the project, carrying the same weight and force as original sections of the plans, specifications, and/or contract documents.

Ensure that you indicate receipt of this Addendum on your Bid.

**Question #1**

Q: I believe there may be a discrepancy in the quantity for curb & gutter.

Sheet 3-1 - 1156.3'

Sheet 3-2 - 811.3' (west of Jacquez Rd)

Sheet 3-2 - 339.5 (east of Jacquez Rd)

Sheet 3-2 - 494' (south side)


Sheet 3-3 - 60' at Drop Inlets locations

The total for these is 2,861 LF. There's a bid quantity of 1650 LF so the difference is 1,211 LF. Can you get verification?

A: Below are the project curb dimensions. The Bid sheet will be revised to the quantities shown below.

Build Curb				Length		
Sta			To			
	0+42.32	14.00 lt		6+51.01	17.79 lt	605.47
	6+75.01	17.79 lt		7+71.99	17.89 lt	107.77
	8+01.91	17.89 lt		11+68.85	17.90 lt	375.1
	12+01.45	17.90 lt		12+55.74	17.90 lt	55.99
	12+96.37	17.90 lt		17+25.94	52.79 lt	458.13
	17+65.95	48.84 lt		20+74.65	20.00 lt	335.34
	15+81.10	14.00 rt		20+74.65	20.00 rt	493.9
	21+95.71	39.42 rt		drop inlet		14
	22+66.59	20.00 rt		drop inlet		28
	22+66.59	20.00 lt		drop inlet		18

Total            2491.7  
Use                2495



CHC Engineers, LLC

**Revised Bid Sheet**

See attached revised Bid Sheet

**End of Addendum**

Ensure that you indicate receipt of this Addendum on your Bid.

**ITB 2024-845 McWILLIAMS ROAD IMPROVEMENT PROJECT**

ITEM	DESCRIPTION	UNIT	QUANTITY	UNIT COST	TOTAL
1	Haul excess material	CY	2800		
2	Subgrade Grading and Compaction for roadway	SY	5890		
3	6" Base Course - Roadway	SY	5890		
4	3" HMA Pavement - Roadway	SY	5890		
5	Paved Driveway	SY	128		
6	Concrete Driveway	SY	104		
7	Ditch grading	LF	563		
8	Ditch landscaping	SY	905		
9	Adjust MH to grade	EA	2		
10	Adjust water valve to grade	EA	1		
11	18" RCP complete in place	LF	70		
12	24" RCP complete in place	LF	64		
13	Single Drop Inlet	EA	1		
14	Double Drop inlet	EA	2		
15	Curb and Gutter	LF	2495		
16	Remove Curb	LF	1045		
17	3' Valley Gutter	LF	36		
18	Sidewalk - 4" thickness	SY	359		
19	Remove Sidewalk	SY	23		
20	Base	SY	1740		
21	Dry Stacked Retaining Wall	LF	560		
22	Cable Fence	LF	515		
23	Gate	EA	2		
24	Construction Testing Allowance	LS	1		
25	Construction Staking by Contractor	LS	1		
26	Traffic Control	LS	1		
27	Mobilization	LS	1		
				<b>Bid Total:</b>	