



**ITB #2019-002 LMIG-Asphalt Leveling & Resurfacing of Various County Roads  
QUESTIONS & ANSWERS  
CLARIFICATION ON SPECIFICATIONS  
ADDENDUM 1**

**Return to:** Lumpkin County Board of Commissioners  
Ryan McDuffie, Purchasing Agent  
99 Courthouse Hill, Suite D  
Dahlonega, GA 30533

**Bid Closing Date:** February 28, 2019 at 2:00 PM, EST  
**Bid Issue Date:** January 30, 2019  
**Addendum Issue Date:** February 22, 2019 at 5:00 PM, EST  
**Pages:** 3  
**By:** Ryan McDuffie, Purchasing Agent


**Vendor Name:** \_\_\_\_\_  
(A copy must be attached to the Addenda Acknowledgement)

---

**QUESTIONS**


1. What will be the work hours for the asphalt leveling and resurfacing project?
  - a. Contractor's discretion but no work on Sundays.
2. Does the County intend to use 9.5MM TP1 for the leveling as in prior years?
  - a. Yes, 9.5MM TPI will be used.
3. Will the County allow the contractor to use portable advance warning signs on tripods or will the County require the use of post mounted signs?
  - a. Construction signs will be allowed on temporary mounts. Low and soft shoulder signs will have to be permanently placed on posts.
4. Will the County require the contractor to pave back to the radius points at side streets and driveways or are we to pave straight through them?
  - a. Major intersections will have to be paved back to the radius. Pave straight through driveways but a lip needs to be extended on to the driveways.
5. Can we use CRS2?
  - a. Yes, it is in the specs.

Figure 6-2 Sign installation detail provided  
Bidder's Certification with signature page included



FRONT VIEW

POST	STUB SIZE
TYPE 7	2 1/4" x 2 1/4"
TYPE 8	2 3/4" x 2 3/4"
TYPE 9	2 1/2" x 2 1/2"



SECTION A-A

FIGURE 6-2

SLIP BASE		
TYPE 7 2 1/4"		
Sign Centroid	1 Post	2 Post
	SQUARE	
8'	9.00	18.00
9'	9.00	18.00
10'	9.10	18.20
11'	7.10	14.20
12'	6.80	13.60
13'	6.25	12.50
14'	5.80	11.60
15'	5.00	10.00
16'	4.70	9.40
17'	4.40	8.80
18'	4.15	8.30
19'	3.95	7.90
20'	3.75	7.50

Sign Centroid is distance from ground level.  
EXAMPLE: 24" x 48" sign that is 7 feet from ground.  
Sign plate shall not exceed 48" in width on

TYPE 9 INSERT SHALL BE A CONTINUOUS F  
THE BOTTOM OF THE SLIP BASE UP TO A  
THE BOTTOM OF THE SIGN. PAYMENT FOR

GROUND MOUNTED BREAKAWAY SIGN SUPPORT  
FOR AT THE UNIT PRICE. MEASUREMENT F  
CLASS A CONCRETE, AND ALL HARDWARE I

**BIDDER'S CERTIFICATION**  
***ITB #2019-002 SAFETY IMPROVEMENTS FOR VARIOUS COUNTY ROADS***

**Date of Bid** \_\_\_\_\_

I certify that this Bid is submitted without prior understanding, agreement or connection with any corporation, firm or person submitting a Bid for the same goods/services and is in all respects fair and without collusion or fraud. I understand that collusive bidding is a violation of State and Federal law and can result in fines, prison sentences and civil damages awards. I agree to abide by all terms and conditions stated of this bid document and certify that I am authorized to sign this bid for the bidder.

I acknowledge that this Project will be constructed in English units.

I certify that I have carefully examined the Plans for this Project and the Standard Specifications, 2013 Edition, the Supplemental Specifications, Manual on Uniform Traffic Control Devices, and Special Provisions included in and made a part of this Bid, and have also personally examined the site of the work. On the basis of the said Scope of Work and Specifications, I propose to furnish all necessary machinery, tools, apparatus and other means of construction, and do all the work and furnish all the materials in the manner specified.

I understand the quantities mentioned are approximate only and are subject to either increase or decrease and hereby propose to perform any increased or decreased quantities of work or extra work on the basis provided for in the Specifications.

I also hereby agree that Lumpkin County would suffer damages in a sum equal to at least the amount of the enclosed Bid Guaranty, in the event my Bid should be accepted and a Contract tendered me there under and I should refuse to execute same and furnish bond as herein required, in consideration of which I hereby agree that, in the event of such failure on my part to execute said Contract and furnish bond within fifteen (15) days after the date of the letter transmitting the Contract to me, the amount of said Bid Guaranty shall be and is hereby, forfeited to Lumpkin County, as liquidated damages as the result of such failure on my part.

I further agree to execute a Contract prepared by Lumpkin County as soon as the work is awarded to me, and to begin and complete the work within the time limit provided. I also propose to furnish the Bonds as required by the Bid Documents and laws of the State of Georgia. Such bond(s) shall not only serve to guarantee the completion of the work on my part, but also to guarantee the excellence of both workmanship and materials until the work is finally accepted, as well as to fully comply with all the laws of the State of Georgia and Lumpkin County.

**Name & Title of Person Authorized to Sign**

\_\_\_\_\_  
Name

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
Title

Sworn to and signed before me, a Notary Public, this \_\_\_\_\_ day of \_\_\_\_\_, in the year \_\_\_\_\_.  
\_\_\_\_\_. Notary Public in and for the county of \_\_\_\_\_,  
\_\_\_\_\_, State of \_\_\_\_\_.

Notary Public Signature and Seal: \_\_\_\_\_

My Commissioner Expires: \_\_\_\_\_

**Bids not signed shall be declared as "Non-Responsive" and may not be considered for award.**