



## **Addendum No. 1**

**Date of Addendum Issuance:** October 21, 2019

**Project:** Old Phoenix Road Auxiliary Lane Construction

**Bid Item #:** 19-42001-003

The following are responses to questions received on Friday, October 18<sup>th</sup>, 2019 at 4:04 PM:

**Question#1:** Will the Asphalt Spec be GDOT DECEL Standard (8in. of 25mm, 2in. of 19mm, 2in of 12.5mm), the plans do not show this spec nor do they specify thickness

**Response:** The pavement section will be as follows:

**1.5 inches – 12.5mm**

**2.0 inches – 19mm**

**4.0 inches – 25 mm**

**Question #2:** Will the Contractor have to be GDOT Prequalified

**Response:** Yes

**Question #3:** Will the Contractor have to be GA General Contractor or Utility Contractor?

**Response:** Either will be sufficient but GDOT pre-qualified is a requirement