

4049 Reid Street • P.O. Box 1429 • Palatka, FL 32178-1429 • 386-329-4500 • www.sjrwmd.com

DATE: January 8, 2024

TO: Interested Firms

FROM: Breanna Pierce, Procurement Specialist

SUBJECT: Addendum 2 to Quote Request, 39361 – Refurbish Walkways/Platforms In Upper Basin Indian River and Brevard County

As a result of questions received from potential respondents, please be advised of the following changes to the subject Request for Proposal:

- 1. The time and date for the submittal of responses remains the same: <u>2:00 p.m. Thursday, January 18,</u> <u>2024.</u>
- 2. Question: What was the winning bid for the last remodeling of these similar sites?

We do not have a similar project that has been completed recently. The last project that we did the contractor provided the material for 3 walkways of varying sizes. The total price was \$38,000.00.

- 3. Question: Is the material true 2 x 6 (2" thick) or (1.5" thick)? The material is 1.5" x 5.5".
- 4. **Question:** Do you require an actual (countersink) for the screws or do you just want the head of the screws ran in below the surface of the wood at least 1/16"?

Below the surface of the wood

5. Question: 1/4" screws does not seem correct. Inspecting some recent remodeled boardwalks, the decking is installed with more common #10 screws (1/4 is #14). 1/4" screw is 20% of the width of the stringers being used (1 1/2" thick).305 stainless (recommended for freshwater) screws 1/4 x 5 inches are over \$1.10 each, when purchased in bulk. It takes at least 6 of these for each decking board. If 1/4" screws are used, all holes will have to be pre-drilled or stringers will surely split. Are the 1/4 stainless screws requirements, correct??

In lieu of using the $\frac{1}{4}$ " screws, we will be using stainless steel #10 3/16" x 3 $\frac{1}{2}$ " "deck screws".

NOTE: Please acknowledge receipt of this Addendum in your submittal.

If you have any questions regarding this addendum, contact Breanna Pierce at (386) 643-1168 or via email at bpierce@sjrwmd.com.