



# St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

---

4049 Reid Street • P.O. Box 1429 • Palatka, FL 32178-1429 • 386-329-4500 • [www.sjrwmd.com](http://www.sjrwmd.com)

DATE: January 12, 2024

TO: Interested Firms

FROM: Breanna Pierce, Procurement Specialist

SUBJECT: Addendum 4 to Quote Request, 39361 – Refurbish Walkways/Platforms In Upper Basin Indian River and Brevard County

As a result of questions received from potential respondents, please be advised of the following changes to the subject Quote Request:

1. The time and date for the submittal of responses remains the same: **2:00 p.m. Thursday, January 18, 2024.**
2. **Question:** What is the manufacture and profile of decking material? We have used several dozen composite decking materials and each one has different screw requirements; some manufactures even have their own screws to prevent cracking and splitting. There are also some manufactures that require the coating of cut ends of composite decking in order for the warranty to be effective.  
**The composite lumber that will be supplied for the project is Trex Select Composite Lumber. The #10 deck screw has been used in the past with no issue.**

**NOTE:** Please acknowledge receipt of this Addendum in your submittal.

If you have any questions regarding this addendum, contact Breanna Pierce at (386) 643-1168 or via email at [bpierce@sjrwmd.com](mailto:bpierce@sjrwmd.com).