

ADDENDUM NO. 3

DATE: January 4, 2019

TO: All Bidders

FROM: Penny Owens, Assistant Purchasing Agent, City of Knoxville

SUBJECT: Addendum No. 3 to the Invitation to Bid for Fire Station #17 Roof Repair

BID DATE: January 10, 2019, at 11:00:00 a.m. Eastern Time

This addendum is being published to respond to questions asked by potential bidders regarding the above-referenced Invitation to Bid. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

Updated Drawings and Clarifications. The revised plan sheets are posted at the link provided to those who submitted a Bid Document Request form and is titled "Addendum No 3 revised plans.pdf".

Question 1: A1.1 Note 4 calls for T11 vertical Hardiplank Sheathing. 5/A1.5 calls for James Hardie ZX-10 Sierra 8 siding. Please clarify.

Response: Sheet A1.1, note 4 has been revised.

Question 2: Please confirm that the new gutters and downspouts are limited to the area that will be reframed, and not the entire building.

Response: New gutters & downspouts are limited to the left and right lower front roof area. Sheet A1.1, locations for note 7 have been revised. All other gutters and downspouts are to remain. Repair or replace any damaged gutters due to the construction.

Question 3: A1.0 calls for removing the roof sheathing from 1/2 of the **lower** roof only (right side), but A1.4 shows installing new sheathing on all of the **lower** roof. Are we replacing the roof sheathing, fascia board, soffit and vent on the entire **lower** roof or just the right half of the **lower** roof? Please clarify.

Response: Include new roof sheathing for both left and right side lower roofs. See revised demo plan A1.0.

END OF ADDENDUM NO. 3