

OFFICE OF THE SULLIVAN COUNTY PURCHASING AGENT

**3411 HIGHWAY 126 – SUITE 201
BLOUNTVILLE, TN 37617-0569**

**KRISTINIA DAVIS, CPPB
PURCHASING AGENT**

PHONE 423/323-6400

FAX 423/323-7249

Kris.davis@sullivancountytn.gov

ADDENDUM-1

**RE: ITB# 1762102(KD) AVIGILON CAMERA SYSTEM
FOR WEST RIDGE HIGH SCHOOL**

DATE: FEBRUARY 16, 2021

This addendum is issued to clarify and correct an answer given at the pre-bid meeting held on February 11, 2021 at 10:00 a.m.

1. Question was asked about cabling and cameras.

Correct Answer: Indoor cameras will have a surface mount box located next to where camera is to be installed.

Outdoor camera will have a surface mount box located next to where the outdoor sleeve starts. In most cases this sleeve is close to the camera, but they are cases where the sleeves are long and not installed near the camera because of the ceiling configuration.

The successful bidder will need to provide outdoor rated cat 6 cables that connect from the surface mount boxes to the cameras for all outdoor cameras.

END OF ADDENDUM #1