

Roane County Purchasing Department
200 East Race Street, Suite #3
Kingston, Tennessee 37763
Phone 865-376-4317 • Fax 865-376-4318

**ADDENDUM #2
BID B2014-50/204
COMPOSIT SAMPLER**

TO: All Potential Bidders

This addendum forms part of the Bid Documents. It supplements and modifies them as follows:

ITEM #1 – ADDITIONAL INFORMATION

1. Actual bottle configuration(s) desired were not specified. Please specify.
 - a. **Bottle configuration is one bottle.**
2. Suction line and strainer type and length were not specified. Please specify.
 - a. **The suction line can be any diameter. The length of the suction is between 2 to 15 feet.**
3. Need for a pump heater was not clear. Do you want this included?
 - a. **The need for a pump heater is due to the fact these samplers will be outside.**
4. Will you be flowpacing the sampler? If so, please specify type of flow meter (or output signal the meter exports).
 - a. **The sampler needs the capability to flow pace. The type of flow meter is unknown due to the fact the flow meters are part of the bid package.**

Please return this addendum to the Purchasing Department in the bid envelope. If your bid has already been sent and this addendum does not pertain to bid pricing, you may return it via facsimile.

ACKNOWLEDGMENT OF ADDENDUM

The undersigned acknowledges receipt of Addendum #2 – Bid #B2014-50/204.

Name

Title