

ADDENDUM NO. 4

DATE: April 16, 2020
TO: All Potential Bidders
FROM: Penny Owens, Purchasing Agent, City of Knoxville
SUBJECT: Addendum No. 4 – Cumberland Estates Recreation Center Roof Replacement

BIDS TO BE OPENED: April 28, 2020, at 11:00:00 a.m. (Eastern Time)

This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

Specifications for the roof top units (RTU-1 & RTU-2) on page MP202 of the project plans shall be revised to be Trane, 15 Ton, 208-230/3/60, and shall include non-fused disconnect, through base electrical, horizontal duct conversion kit with roof curbs, 0 – 100% economizer, dry bulb controlled, condenser coil hail guard, and 18 kW electrical heater. All other requirements for these units remain unchanged.

ADDENDUM NO. 4