



# CITY OF CONROE

Est. 1904

City of Conroe  
PO Box 3066  
Conroe, Texas 77305

**ADDENDUM NO. 1**

DATE 2-5-2024

PROJECT NAME:

The City of Conroe Candy Cane Park Fitness Area Poured in Place Playground Surfacing Repair


This revision shall be considered part of the contract documents for the above named project, and shall be incorporated integrally with the previously issued documents. Wherein provisions of the revisions differ from the provisions of the original documents and/or the provisions of previously issued addendum, the provisions of this revision shall govern and take precedence.

On page 2 under the Scope of Work, #2. Please strike the sentence, "All materials shall meet a Critical Fall Height of 10 feet." in its entirety.


Reasoning: Most manufactures/installers/repairers cannot guarantee a CFH of 10 feet without knowing the performance of the base SBR layer. Otherwise, all of the companies bidding would have to start from scratch and remove the base layer as well. Only the original installer, should they bid on the project, could guarantee the base layer's performance.

By the signature affixed below, Addendum No. 1 is hereby incorporated into and made a part of the above referenced solicitation.

ACKNOWLEDGED:

  
\_\_\_\_\_

Authorized Signature

  
\_\_\_\_\_

Printed Name

\_\_\_\_\_

Respondent/Contractor

\_\_\_\_\_

Date

2-5-2024

Teri-Lynn Hatch, Buyer Supervisor