

ADDENDUM NUMBER THREE
REPLACEMENT ROOFING SYSTEMS FOR
THE LINDSEY STREET BUILDING
1001 LINDSEY STREET
FOR THE CITY OF CHATTANOOGA, TENNESSEE
Contract Number M-17-006-201

Questions have been received concerning the bid specifications. Below are the questions and the City of Chattanooga's responses to those questions:

Q: Specs call for "flexible fabric-backed TPO". Is this correct, and does this mean this project requires fleece backed TPO.

A: This specification is incorrect. This project does not require fleece backed TPO. Regular .060 TPO is acceptable.

Q: Section 2.3 calls for "TYPE II Class 2" ISO board. Is this correct, and are you asking for Resista polyiso board, or equivalent?

A: This specification is incorrect. This project calls for regular ISO 95+ board.

Due to the late response to these questions, the bid date is being rescheduled. The new bid date is Tuesday, February 13, 2018 at 2:00 p.m.

The City regrets the errors, and apologizes for any confusion.

February 5, 2018

/s/ Justin C. Holland, Administrator
City of Chattanooga
Department of Public Works