



OFFICE OF PROCUREMENT SERVICES
335 FOUR MILE ROAD
CONWAY, SC 29526-6005

AMENDMENT/ADDENDUM No. #1

Posting Date: Thursday, July 30, 2020

Solicitation Number: 2021-1MJ

Description: Ocean Bay Middle School Practice Field Renovation

AMENDMENTS TO SOLICITATION: (a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: <http://apps.hcs.k12.sc.us/apps/protrac/> (b) Offerors shall acknowledge receipt of any amendment to this solicitation (1) by signing and returning the amendment, (2) by letter, or (3) by submitting a bid that indicates in some way that the bidder received the amendment. (c) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged. [02-2A005-1]

QUESTIONS FROM OFFERORS - AMENDMENT (JUN 2017): The solicitation is amended as provided herein. Information or changes resulting from questions will be shown in a question-and-answer format. All questions received have been reprinted below. The "District's Response" should be read without reference to the questions. The questions are included solely to provide a cross-reference to the potential offeror that submitted the question. Questions do not form a part of the contract. The "District's Response" does. Any restatement of part or all of an existing provision of the solicitation in an answer does not modify the original provision except as follows: underline text is added to the original provision. Stricken text is deleted. [02-2A097-1]

BID OPENING DATE AND TIME REMAIN THE SAME

Question Number	Question	Answer
1.	Please provide the existing drainage pipe size associated with the Catch Basin relocations.	The inside diameter is 18".
2.	Is the contractor and/or subcontractor required to be a "certified sports field builder"?	It is preferred not required.

HORRY COUNTY SCHOOLS

By:

Robin B. Strickland, CPPB
Procurement Officer