



FAYETTE COUNTY PUBLIC SCHOOLS

Addendum to Solicitation

Addendum No. Bid

1 05-22 Asbestos Abatement TCHS Phase 2

Description of Addendum is as follows:

- Changes and additions to the scope of work and solicitation
- Pre-bid meeting minutes and attendance

Changes and additions to the scope of work and solicitation

1. There are fire doors in the scope of work for all areas of abatement. They are detailed in the attached drawing. The total number has changed and two areas now reflect more doors than related during the pre-bid meeting.

Note that doors that appear in Area F should be treated as two in Area B and two in area D. There is no abatement in Area F.

The Owner will aid in identification of the locations of these doors.

2. Liquidated Damages: In the event of delay in abatement completion, the Contractor shall pay liquidated damages in the amount of \$2,500.00 per day.

3. The start dates for each area of abatement are likely to change. The dates would be uniformly one week earlier. The length of time accorded to each area would remain the same. The completion dates would therefore also be one week earlier.

4. The number of pipe fittings in Area E, item number one, should be reduced by 50 fittings, to approximately 70 fittings. They will be primarily in the locker rooms and adjoining rooms under the bleachers.


Bidders shall acknowledge receipt of this addendum and changes to solicitation by signing below. Except as provided in this addendum, all terms and conditions of the solicitation remain unchanged and in full force and effect. A signed copy of the addendum must be included with the bid submission or bid may not be considered.

Name of Firm

Signature

Date

Print Name and Title



Phase 2-Abatement
plan for Existing Tates
Creek High School

Pre-bid meeting minutes and attendance

Explained bid opening date, advised to get bids turned in early due to weather

Question was asked regarding last day of school – 5/24

Question asked how bid would be awarded when asking for pricing for 2 different types. Answer was the district has not decided which way to go and that will be decided based on the pricing received. There is a possibility of multiple contractors doing work at the same time and individual areas will be awarded. If there is a low bidder for all areas they will be given first preference on which areas they want to work with.

Question regarding drop ceiling tiles and hard ceiling. Contractor is not responsible for disposal of tiles. Not sure which tiles will need to be removed.

Floor tiles have asbestos? Disposal?

Most tiles that had asbestos have been removed but mastic does have asbestos. Disposal of tiles is responsibility of contractor, tiles may have mastic on them.

Ceiling tile, plaster ceilings and concrete walls disturbed in accessing pipe fittings do not have to be cleaned up by this contract.

Water and electric will be available through the removal process.

PLEASE SIGN IN

Bid:05-22 Asbestos TCHS Phase 2
Date/Time: 1/12/22 2:00PM

WESLEY
HARRIS

Name/ Company	email
Environmental Assurance Co. Inc.	ctrotter@eac.usa.com
ENVIRONMENTAL SPECIALITIES INC	PWESHAM@HOTMAIL.COM
Jeff Harris / FCPS	jeff.harris@dayette.kyschools.us
Mike McGonigle / ASTI	support@airsourcetechnology.com
Environmental Demolition Group	smeginness@edgllc.biz
Enviroworx	Jmonks@enviroworx.net
Matt Moore FCPS	
Gunesis Environmental	ksullivan@sunriseenv.com