

**ARLINGTON COUNTY, VIRGINIA
OFFICE OF THE PURCHASING AGENT**

INVITATION TO BID NO. 23-DES-ITBPW-447

ADDENDUM NO. 1

Arlington County Invitation to Bid No. 23-DES-ITBPW-447 for Replacement of six Automatic Transfer Switches (ATS) is amended as follows:

1. Bid Due Date is hereby changed to:

ELECTRONIC SEALED BIDS WILL BE RECEIVED BY ARLINGTON COUNTY VIA VENDOR REGISTRY UNTIL **2:30 P.M. ON THE 8TH DAY OF FEBRUARY 2023.**

The County will conduct a virtual bid opening via Microsoft Teams Application (APP). Bidders interested in viewing the public bid opening must download the APP and join the meeting via the Microsoft Teams APP and enable audio, video or both. The link to join the virtual bid opening is provided below:

[Join Microsoft Teams Meeting](#)
[+1 347-973-6905](tel:+13479736905) United States, New York City (Toll)
Conference ID: 486 938 149#

2. Drawings

Attachment C – CP ATS Replacement Construction Set has been revised as follows:

SHEET NO.	DESCRIPTION
E000	
•	Power Riser Diagram
○	Removed Add/Alternate Scopes. Alternate #1 is now part of base-bid scope.
•	Electrical Notes and Specifications
○	Revise note #14.
E101	
•	Keynotes #2 and #6 are removed from the scope of work.
E201	
•	New Work Plan
○	Approximate location of Panel EL12A is shown on the new work plan.
○	Add alternate 2 quick connect box is removed from the scope of work.
•	Detail 2
○	Revised keynote number for ATS-3 and ATS-5/6
•	Detail 3
○	A junction box with circuit is added in the generator room for converter branch circuit.
○	Add/Alternate #2 quick connect box removed from the scope of work.
○	Day-tank revisions (keynotes 2 and 3) removed from scope of work.
○	Add/Alternate #1 included in scope of base-bid (keynote 10).

- General
 - Keynote #1 is revised to indicate the converter branch circuit.
 - Keynotes #2 and #3 are removed from the scope of work.
 - Keynotes #5, #6, and #8 are revised for additional information.
 - Keynote #10 is added.
 - Housekeeping pad extension notes are added.
 - Add alternate notes are removed.

E502

- Temporary work keynote #4 is revised to indicate 2-sets of 4-#500KCMIL.

3. Specifications

Attachment D – CP ATS Replacement has been revised as follows:

- Table Of Contents
 - Deleted Section 016600 - TESTING, ADJUSTING AND BALANCING OF SYSTEMS.
 - Added Section 260573.19 - ARC-FLASH HAZARD ANALYSIS.
- Section 016600 - TESTING, ADJUSTING AND BALANCING OF SYSTEMS
 - Deleted specification section.
- Section 260573.19 - ARC-FLASH HAZARD ANALYSIS
 - Added specification section.

4. Vendor Questions

A list of vendor questions and answers is attached.

The balance of the solicitation remains unchanged.

Arlington County, Virginia

Sy Gezachew
sgezachew@arlingtonva.us
 Procurement Officer

RETURN THIS PAGE, FULLY COMPLETED AND SIGNED, WITH YOUR BID:

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM NUMBER 1.

FIRM NAME: _____

AUTHORIZED SIGNATURE: _____ **DATE:** _____