

**ADDENDUM NUMBER 4
BID NUMBER IFB 20-023**

SUMMER ROOFING PROJECTS 2021

ISSUED: January 14, 2021

**PURCHASING DEPARTMENT
UNIFIED SCHOOL DISTRICT 500
2010 N. 59th STREET, ROOM 370
KANSAS CITY, KANSAS 66104
(913) 551-3200**

Note the following changes to the above-mentioned bid. This information is to be taken into consideration when responding to the original bid document.

1. **Delete and Replace:** Addendum 3, Section II – Specification Adds, Deletions, and/or Changes, Subsection F, 4 (Page 4 of 6), is hereby deleted in its entirety and replaced as follows (word changed highlighted):
 4. Include in your bid **repositioning** of the south Trane RTU on Roof 2 by Stanger Industries.
 - a. Stanger contact: Matt Stone – 816-288-8710
 - b. Include the installation of new duct curbs and flashing on Roof 3 as specified by Stanger.
 - c. Include the infill and covering of voids in the brick wall where existing ducts will be removed.
 - 1) Fill voids with polyisocyanurate insulation to match the thickness of the wall.
 - 2) Cover voids with 22-gauge metal plates lapping over voids a minimum of four inches on each side.
 - a) Install double sided butyl tape between the brick wall and new metal plates along 100% of all edges.
 - b) Fasten to brick wall with masonry anchors six inches on center.
2. **No Other Changes:** No other changes or modification are intended by this Addendum. All other terms and conditions of the solicitation remain in effect.

WE HEREBY ACKNOWLEDGE AND UNDERSTAND THE ABOVE NOTED CHANGES TO THE ORIGINAL BID DOCUMENT AND AGREE TO FURNISH THE ITEMS ON WHICH PRICES ARE QUOTED IN ACCORDANCE WITH ALL TERMS AND CONDITIONS PREVIOUSLY LISTED AND ANY ATTACHED SPECIFICATIONS AND AMENDMENTS.

BY: _____ DATE: _____
TITLE: _____ PHONE: _____
FIRM _____