

City of Havelock
Westbrooke Pump Station, Discharge Pipe Leak Repair
Addendum 2
April 3, 2017

The following questions were received:

1. Is there any information on the flow/hour or flow/ day in this pump station to size the bypass pumps?
2. Is there an existing line connection for the bypass pump(s)?

Answer:

1. Westbrooke Lift Station has approximately 200,000 gallons per day of flow.
2. The bypass pump needed appears to be a 4" pump, connecting to a 3" male cam lock connection. The bypass pump shall need to pump from the manhole in front of the station, approximately 100' from the bypass connection. Contractor to verify the size of pump required.

Thank you for your continued interest in our project.

CITY OF HAVELOCK

Lee W. Tillman 4-3-17

Lee W. Tillman

Finance Director